

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITY TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOC ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	001F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-002	Weese, Bret	12/17/2016	08:17:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	001F	Kitchen Faucet Cold	KC	Copper	0.141	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-002	Weese, Bret	12/17/2016	08:17:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	001P	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-001	Weese, Bret	12/17/2016	08:15:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	001P	Kitchen Faucet Cold	KC	Copper	0.161	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-001	Weese, Bret	12/17/2016	08:15:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	002F	Kitchen Kettle Cold	KK	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-004	Weese, Bret	12/17/2016	08:21:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	002F	Kitchen Kettle Cold	KK	Copper	0.168	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-004	Weese, Bret	12/17/2016	08:21:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	002P	Kitchen Kettle Cold	KK	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-003	Weese, Bret	12/17/2016	08:19:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	002P	Kitchen Kettle Cold	KK	Copper	0.0431	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-003	Weese, Bret	12/17/2016	08:19:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	003F	Drinking Water Fountain - Main Hall by Dishwash Ro	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-006	Weese, Bret	12/17/2016	08:29:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	003F	Drinking Water Fountain - Main Hall by Dishwash Ro	DW	Copper	0.0636	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-006	Weese, Bret	12/17/2016	08:29:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	003P	Drinking Water Fountain - Main Hall by Dishwash Ro	DW	Lead	0.0020	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-005	Weese, Bret	12/17/2016	08:28:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	003P	Drinking Water Fountain - Main Hall by Dishwash Ro	DW	Copper	0.0747	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-005	Weese, Bret	12/17/2016	08:28:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	004F	Drinking Water Fountain Room 20	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-008	Weese, Bret	12/17/2016	08:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	004F	Drinking Water Fountain Room 20	DW	Copper	0.0660	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-008	Weese, Bret	12/17/2016	08:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	004P	Drinking Water Fountain Room 20	DW	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-007	Weese, Bret	12/17/2016	08:35:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	004P	Drinking Water Fountain Room 20	DW	Copper	0.289	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-007	Weese, Bret	12/17/2016	08:35:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	005F	Classroom Faucet Room 20	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-010	Weese, Bret	12/17/2016	08:39:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	005F	Classroom Faucet Room 20	CF	Copper	0.0205	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-010	Weese, Bret	12/17/2016	08:39:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	005P	Classroom Faucet Room 20	CF	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-009	Weese, Bret	12/17/2016	08:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	005P	Classroom Faucet Room 20	CF	Copper	0.260	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-009	Weese, Bret	12/17/2016	08:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	006F	Drinking Water Fountain Room 19	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-012	Weese, Bret	12/17/2016	08:43:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	006F	Drinking Water Fountain Room 19	DW	Copper	0.0767	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-012	Weese, Bret	12/17/2016	08:43:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	006P	Drinking Water Fountain Room 19	DW	Lead	0.0018	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-011	Weese, Bret	12/17/2016	08:41:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	006P	Drinking Water Fountain Room 19	DW	Copper	0.134	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-011	Weese, Bret	12/17/2016	08:41:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	007F	Classroom Faucet Room 19	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-014	Weese, Bret	12/17/2016	08:46:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	007F	Classroom Faucet Room 19	CF	Copper	0.0789	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-014	Weese, Bret	12/17/2016	08:46:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	007P	Classroom Faucet Room 19	CF	Lead	0.0022	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-013	Weese, Bret	12/17/2016	08:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	007P	Classroom Faucet Room 19	CF	Copper	0.131	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-013	Weese, Bret	12/17/2016	08:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	008F	Drinking Water Fountain Room 18	DW	Lead	0.0180	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-016	Weese, Bret	12/17/2016	08:49:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	008F	Drinking Water Fountain Room 18	DW	Copper	0.266	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-016	Weese, Bret	12/17/2016	08:49:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	008P	Drinking Water Fountain Room 18	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-015	Weese, Bret	12/17/2016	08:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	008P	Drinking Water Fountain Room 18	DW	Copper	0.174	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-015	Weese, Bret	12/17/2016	08:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	009F	Classroom Faucet Room 18	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-018	Weese, Bret	12/17/2016	08:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	009F	Classroom Faucet Room 18	CF	Copper	0.102	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-018	Weese, Bret	12/17/2016	08:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	009P	Classroom Faucet Room 18	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-017	Weese, Bret	12/17/2016	08:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	009P	Classroom Faucet Room 18	CF	Copper	0.150	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-017	Weese, Bret	12/17/2016	08:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	010F	Drinking Water Fountain Room 17	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-020	Weese, Bret	12/17/2016	08:55:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	010F	Drinking Water Fountain Room 17	DW	Copper	0.204	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-020	Weese, Bret	12/17/2016	08:55:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	010P	Drinking Water Fountain Room 17	DW	Lead	0.0021	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-019	Weese, Bret	12/17/2016	08:53:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	010P	Drinking Water Fountain Room 17	DW	Copper	0.259	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-019	Weese, Bret	12/17/2016	08:53:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	011F	Classroom Faucet Room 17	CF	Lead	0.0010	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-022	Weese, Bret	12/17/2016	08:58:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	011F	Classroom Faucet Room 17	CF	Copper	0.149	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-022	Weese, Bret	12/17/2016	08:58:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	011P	Classroom Faucet Room 17	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-021	Weese, Bret	12/17/2016	08:56:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	011P	Classroom Faucet Room 17	CF	Copper	0.134	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-021	Weese, Bret	12/17/2016	08:56:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	012F	Drinking Water Fountain Room 16	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-024	Weese, Bret	12/17/2016	09:01:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	012F	Drinking Water Fountain Room 16	DW	Copper	0.245	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-024	Weese, Bret	12/17/2016	09:01:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	012P	Drinking Water Fountain Room 16	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-023	Weese, Bret	12/17/2016	08:59:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	012P	Drinking Water Fountain Room 16	DW	Copper	0.285	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-023	Weese, Bret	12/17/2016	08:59:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	013F	Classroom Faucet Room 16	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-026	Weese, Bret	12/17/2016	09:04:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	013F	Classroom Faucet Room 16	CF	Copper	0.0997	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-026	Weese, Bret	12/17/2016	09:04:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	013P	Classroom Faucet Room 16	CF	Lead	0.0089	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-025	Weese, Bret	12/17/2016	09:02:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	013P	Classroom Faucet Room 16	CF	Copper	0.327	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-025	Weese, Bret	12/17/2016	09:02:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	014F	Classroom Fountain Room 15	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-028	Weese, Bret	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	014F	Classroom Fountain Room 15	CF	Copper	0.398	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-028	Weese, Bret	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	014P	Classroom Fountain Room 15	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-027	Weese, Bret	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	014P	Classroom Fountain Room 15	CF	Copper	0.327	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-027	Weese, Bret	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	015F	Drinking Water Fountain Room 15	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-030	Weese, Bret	12/17/2016	09:10:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	015F	Drinking Water Fountain Room 15	DW	Copper	0.0871	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-030	Weese, Bret	12/17/2016	09:10:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	015P	Drinking Water Fountain Room 15	DW	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-029	Weese, Bret	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	015P	Drinking Water Fountain Room 15	DW	Copper	0.439	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-029	Weese, Bret	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	016F	Classroom Fountain Room 14	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-032	Weese, Bret	12/17/2016	09:14:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	016F	Classroom Fountain Room 14	CF	Copper	0.579	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-032	Weese, Bret	12/17/2016	09:14:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	016P	Classroom Fountain Room 14	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-031	Weese, Bret	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	016P	Classroom Fountain Room 14	CF	Copper	0.533	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-031	Weese, Bret	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	017F	Drinking Fountain Room 14	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-034	Weese, Bret	12/17/2016	09:18:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	017F	Drinking Fountain Room 14	DW	Copper	0.255	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-034	Weese, Bret	12/17/2016	09:18:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	017P	Drinking Fountain Room 14	DW	Lead	0.0030	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-033	Weese, Bret	12/17/2016	09:15:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	017P	Drinking Fountain Room 14	DW	Copper	0.495	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-033	Weese, Bret	12/17/2016	09:15:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	018F	Drinking Water Bubbler Room 13	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-036	Weese, Bret	12/17/2016	19:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	018F	Drinking Water Bubbler Room 13	DW	Copper	0.0572	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-036	Weese, Bret	12/17/2016	19:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	018P	Drinking Water Bubbler Room 13	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-035	Weese, Bret	12/17/2016	09:20:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	018P	Drinking Water Bubbler Room 13	DW	Copper	0.206	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-035	Weese, Bret	12/17/2016	09:20:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	019F	Classroom Faucet Room 13	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-038	Weese, Bret	12/17/2016	09:24:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	019F	Classroom Faucet Room 13	CF	Copper	0.0578	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-038	Weese, Bret	12/17/2016	09:24:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	019P	Classroom Faucet Room 13	CF	Lead	0.0060	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-037	Weese, Bret	12/17/2016	09:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	019P	Classroom Faucet Room 13	CF	Copper	0.105	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-037	Weese, Bret	12/17/2016	09:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	020F	Drinking Water Bubbler Room 12	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-040	Weese, Bret	12/17/2016	09:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	020F	Drinking Water Bubbler Room 12	DW	Copper	0.0478	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-040	Weese, Bret	12/17/2016	09:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	020P	Drinking Water Bubbler Room 12	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-039	Weese, Bret	12/17/2016	09:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	020P	Drinking Water Bubbler Room 12	DW	Copper	0.213	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-039	Weese, Bret	12/17/2016	09:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	021F	Classroom Faucet Room 12	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-042	Weese, Bret	12/17/2016	09:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	021F	Classroom Faucet Room 12	CF	Copper	0.0705	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-042	Weese, Bret	12/17/2016	09:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	021P	Classroom Faucet Room 12	CF	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-041	Weese, Bret	12/17/2016	09:28:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	021P	Classroom Faucet Room 12	CF	Copper	0.143	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-041	Weese, Bret	12/17/2016	09:28:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	022F	Drinking Water Bubbler Room 11	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-044	Weese, Bret	12/17/2016	09:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	022F	Drinking Water Bubbler Room 11	DW	Copper	0.0321	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-044	Weese, Bret	12/17/2016	09:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	022P	Drinking Water Bubbler Room 11	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-043	Weese, Bret	12/17/2016	09:31:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	022P	Drinking Water Bubbler Room 11	DW	Copper	0.0538	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-043	Weese, Bret	12/17/2016	09:31:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	023F	Classroom Faucet Room 11	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-046	Weese, Bret	12/17/2016	09:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	023F	Classroom Faucet Room 11	CF	Copper	0.0273	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-046	Weese, Bret	12/17/2016	09:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	023P	Classroom Faucet Room 11	CF	Lead	0.0020	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-045	Weese, Bret	12/17/2016	09:33:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	023P	Classroom Faucet Room 11	CF	Copper	0.0941	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-045	Weese, Bret	12/17/2016	09:33:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	024F	Drinking Fountain Room 10	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-048	Weese, Bret	12/17/2016	09:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	024F	Drinking Fountain Room 10	DW	Copper	0.0345	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-048	Weese, Bret	12/17/2016	09:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	024P	Drinking Fountain Room 10	DW	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-047	Weese, Bret	12/17/2016	09:36:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	024P	Drinking Fountain Room 10	DW	Copper	0.166	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-047	Weese, Bret	12/17/2016	09:36:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	025F	Classroom Faucet Room 10	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-050	Weese, Bret	12/17/2016	09:39:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	025F	Classroom Faucet Room 10	CF	Copper	0.0209	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-050	Weese, Bret	12/17/2016	09:39:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	025P	Classroom Faucet Room 10	CF	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-049	Weese, Bret	12/17/2016	09:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	025P	Classroom Faucet Room 10	CF	Copper	0.101	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-049	Weese, Bret	12/17/2016	09:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	027F	Classroom Faucet Room 9	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-052	Weese, Bret	12/17/2016	09:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	027F	Classroom Faucet Room 9	CF	Copper	0.0150	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-052	Weese, Bret	12/17/2016	09:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	027P	Classroom Faucet Room 9	CF	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-051	Weese, Bret	12/17/2016	09:42:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	027P	Classroom Faucet Room 9	CF	Copper	0.127	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-051	Weese, Bret	12/17/2016	09:42:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	028F	Classroom Faucet Library Office	CF	Lead	0.0766	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-054	Weese, Bret	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	028F	Classroom Faucet Library Office	CF	Copper	0.730	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-054	Weese, Bret	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	028P	Classroom Faucet Library Office	CF	Lead	0.0975	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-053	Weese, Bret	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	028P	Classroom Faucet Library Office	CF	Copper	0.406	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-053	Weese, Bret	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	029F	Classroom Faucet Library Work Area	CF	Lead	0.704	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-056	Weese, Bret	12/17/2016	10:00:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	029F	Classroom Faucet Library Work Area	CF	Copper	4.91	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-056	Weese, Bret	12/17/2016	10:00:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	029P	Classroom Faucet Library Work Area	CF	Lead	0.617	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-055	Weese, Bret	12/17/2016	09:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	029P	Classroom Faucet Library Work Area	CF	Copper	1.68	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-055	Weese, Bret	12/17/2016	09:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	034F	Drinking Water Fountain Room 6	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-058	Weese, Bret	12/17/2016	10:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	034F	Drinking Water Fountain Room 6	DW	Copper	0.149	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-058	Weese, Bret	12/17/2016	10:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	034P	Drinking Water Fountain Room 6	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-057	Weese, Bret	12/17/2016	10:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	034P	Drinking Water Fountain Room 6	DW	Copper	0.125	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-057	Weese, Bret	12/17/2016	10:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	035F	Classroom Faucet Room 6	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-060	Weese, Bret	12/17/2016	10:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	035F	Classroom Faucet Room 6	CF	Copper	0.0923	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-060	Weese, Bret	12/17/2016	10:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	035P	Classroom Faucet Room 6	CF	Lead	0.0010	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-059	Weese, Bret	12/17/2016	10:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	035P	Classroom Faucet Room 6	CF	Copper	0.125	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-059	Weese, Bret	12/17/2016	10:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	037F	Classroom Faucet Room 5	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-062	Weese, Bret	12/17/2016	10:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	037F	Classroom Faucet Room 5	CF	Copper	0.0894	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-062	Weese, Bret	12/17/2016	10:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	037P	Classroom Faucet Room 5	CF	Lead	0.0039	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-061	Weese, Bret	12/17/2016	10:31:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	037P	Classroom Faucet Room 5	CF	Copper	0.125	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-061	Weese, Bret	12/17/2016	10:31:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	038F	Classroom Faucet Room 5A	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-064	Weese, Bret	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	038F	Classroom Faucet Room 5A	CF	Copper	0.202	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-064	Weese, Bret	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	038P	Classroom Faucet Room 5A	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-063	Weese, Bret	12/17/2016	10:36:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	038P	Classroom Faucet Room 5A	CF	Copper	0.175	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-063	Weese, Bret	12/17/2016	10:36:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	039F	Drinking Water Fountain Room 5A	DW	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-066	Weese, Bret	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	039F	Drinking Water Fountain Room 5A	DW	Copper	0.183	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-066	Weese, Bret	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	039P	Drinking Water Fountain Room 5A	DW	Lead	0.0086	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-065	Weese, Bret	12/17/2016	10:37:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	039P	Drinking Water Fountain Room 5A	DW	Copper	0.364	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-065	Weese, Bret	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	040F	Drinking Water Fountain Room 4A	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-068	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	040F	Drinking Water Fountain Room 4A	DW	Copper	0.130	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-068	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	040P	Drinking Water Fountain Room 4A	DW	Lead	0.0111	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-067	Weese, Bret	12/17/2016	10:42:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	040P	Drinking Water Fountain Room 4A	DW	Copper	0.129	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-067	Weese, Bret	12/17/2016	10:42:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	041F	Classroom Faucet Room 4A	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-070	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	041F	Classroom Faucet Room 4A	CF	Copper	0.0957	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-070	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	041P	Classroom Faucet Room 4A	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-069	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	041P	Classroom Faucet Room 4A	CF	Copper	0.131	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-069	Weese, Bret	12/17/2016	10:44:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	042F	Drinking Water Fountain Room 4	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-072	Weese, Bret	12/17/2016	10:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	042F	Drinking Water Fountain Room 4	DW	Copper	0.173	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-072	Weese, Bret	12/17/2016	10:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	042P	Drinking Water Fountain Room 4	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-071	Weese, Bret	12/17/2016	10:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	042P	Drinking Water Fountain Room 4	DW	Copper	0.177	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-071	Weese, Bret	12/17/2016	10:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	043F	Classroom Faucet Room 4	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-074	Weese, Bret	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	043F	Classroom Faucet Room 4	CF	Copper	0.138	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-074	Weese, Bret	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	043P	Classroom Faucet Room 4	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-073	Weese, Bret	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	043P	Classroom Faucet Room 4	CF	Copper	0.141	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-073	Weese, Bret	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	044F	Drinking Water Bubbler Reading Room	DW	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-076	Weese, Bret	12/17/2016	10:56:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	044F	Drinking Water Bubbler Reading Room	DW	Copper	0.159	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-076	Weese, Bret	12/17/2016	10:56:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	044P	Drinking Water Bubbler Reading Room	DW	Lead	0.0063	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-075	Weese, Bret	12/17/2016	10:54:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	044P	Drinking Water Bubbler Reading Room	DW	Copper	0.301	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-075	Weese, Bret	12/17/2016	10:54:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	045F	Classroom Faucet Reading Room	CF	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-078	Weese, Bret	12/17/2016	10:59:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	045F	Classroom Faucet Reading Room	CF	Copper	0.0992	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-078	Weese, Bret	12/17/2016	10:59:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	045P	Classroom Faucet Reading Room	CF	Lead	0.0133	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-077	Weese, Bret	12/17/2016	10:57:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	045P	Classroom Faucet Reading Room	CF	Copper	0.0992	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-077	Weese, Bret	12/17/2016	10:57:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	046F	Drinking Water Bubbler Room 2	DW	Lead	0.0023	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-080	Weese, Bret	12/17/2016	11:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	046F	Drinking Water Bubbler Room 2	DW	Copper	0.158	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-080	Weese, Bret	12/17/2016	11:08:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	046P	Drinking Water Bubbler Room 2	DW	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-079	Weese, Bret	12/17/2016	11:06:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	046P	Drinking Water Bubbler Room 2	DW	Copper	0.170	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-079	Weese, Bret	12/17/2016	11:06:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	047F	Classroom Faucet Room 2	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-082	Weese, Bret	12/17/2016	11:10:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	047F	Classroom Faucet Room 2	CF	Copper	0.106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-082	Weese, Bret	12/17/2016	11:10:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	047P	Classroom Faucet Room 2	CF	Lead	0.0039	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-081	Weese, Bret	12/17/2016	11:09:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	047P	Classroom Faucet Room 2	CF	Copper	0.124	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-081	Weese, Bret	12/17/2016	11:09:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	048F	Drinking Water Bubbler Room 1	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-084	Weese, Bret	12/17/2016	11:12:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	048F	Drinking Water Bubbler Room 1	DW	Copper	0.0915	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-084	Weese, Bret	12/17/2016	11:12:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	048P	Drinking Water Bubbler Room 1	DW	Lead	0.0032	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-083	Weese, Bret	12/17/2016	11:11:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	048P	Drinking Water Bubbler Room 1	DW	Copper	0.124	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-083	Weese, Bret	12/17/2016	11:11:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	049F	Classroom Faucet Room 1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-086	Weese, Bret	12/17/2016	11:14:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	049F	Classroom Faucet Room 1	CF	Copper	0.0732	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-086	Weese, Bret	12/17/2016	11:14:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	049P	Classroom Faucet Room 1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-085	Weese, Bret	12/17/2016	11:13:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	049P	Classroom Faucet Room 1	CF	Copper	0.0867	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-085	Weese, Bret	12/17/2016	11:13:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	051F	Classroom Faucet Room 25	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-088	Weese, Bret	12/17/2016	11:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	051F	Classroom Faucet Room 25	CF	Copper	0.125	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-088	Weese, Bret	12/17/2016	11:22:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	051P	Classroom Faucet Room 25	CF	Lead	0.0063	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-087	Weese, Bret	12/17/2016	11:19:00	03-Jan-17



LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	051P	Classroom Faucet Room 25	CF	Copper	0.163	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-087	Weese, Bret	12/17/2016	11:19:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	052F	Drinking Water Bubbler Room 24	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-090	Weese, Bret	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	052F	Drinking Water Bubbler Room 24	DW	Copper	0.159	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-090	Weese, Bret	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	052P	Drinking Water Bubbler Room 24	DW	Lead	0.0024	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-089	Weese, Bret	12/17/2016	11:23:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	052P	Drinking Water Bubbler Room 24	DW	Copper	0.200	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-089	Weese, Bret	12/17/2016	11:23:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	053F	Classroom Faucet Room 24	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-092	Weese, Bret	12/17/2016	11:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	053F	Classroom Faucet Room 24	CF	Copper	0.0875	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-092	Weese, Bret	12/17/2016	11:27:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	053P	Classroom Faucet Room 24	CF	Lead	0.0015	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-091	Weese, Bret	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	053P	Classroom Faucet Room 24	CF	Copper	0.149	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-091	Weese, Bret	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	055F	Classroom Faucet Room 23	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-094	Weese, Bret	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	055F	Classroom Faucet Room 23	CF	Copper	0.106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-094	Weese, Bret	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	055P	Classroom Faucet Room 23	CF	Lead	0.0038	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-093	Weese, Bret	12/17/2016	11:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	055P	Classroom Faucet Room 23	CF	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-093	Weese, Bret	12/17/2016	11:30:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	056F	Drinking Water Bubbler Room 22	DW	Lead	0.0140	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-096	Weese, Bret	12/17/2016	11:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	056F	Drinking Water Bubbler Room 22	DW	Copper	0.469	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-096	Weese, Bret	12/17/2016	11:34:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	056P	Drinking Water Bubbler Room 22	DW	Lead	0.0566	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-095	Weese, Bret	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	056P	Drinking Water Bubbler Room 22	DW	Copper	0.771	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-095	Weese, Bret	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	057F	Classroom Faucet Room 22	CF	Lead	0.0023	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-098	Weese, Bret	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	057F	Classroom Faucet Room 22	CF	Copper	0.262	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-098	Weese, Bret	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	057P	Classroom Faucet Room 22	CF	Lead	0.0059	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-097	Weese, Bret	12/17/2016	11:35:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	057P	Classroom Faucet Room 22	CF	Copper	0.324	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-097	Weese, Bret	12/17/2016	11:35:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	058F	Classroom Faucet Room 21	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-100	Weese, Bret	12/17/2016	11:39:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	058F	Classroom Faucet Room 21	CF	Copper	0.191	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-100	Weese, Bret	12/17/2016	11:39:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	058P	Classroom Faucet Room 21	CF	Lead	0.0021	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-099	Weese, Bret	12/17/2016	11:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	058P	Classroom Faucet Room 21	CF	Copper	0.220	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-099	Weese, Bret	12/17/2016	11:38:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	059F	Drinking Water Bubbler Room 21	DW	Lead	0.0056	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-102	Weese, Bret	12/17/2016	11:41:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	059F	Drinking Water Bubbler Room 21	DW	Copper	0.258	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-102	Weese, Bret	12/17/2016	11:41:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	059P	Drinking Water Bubbler Room 21	DW	Lead	0.0171	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-101	Weese, Bret	12/17/2016	11:40:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	059P	Drinking Water Bubbler Room 21	DW	Copper	0.491	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-101	Weese, Bret	12/17/2016	11:40:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	060F	Nurses Sink Cold	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-104	Weese, Bret	12/17/2016	11:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	060F	Nurses Sink Cold	NS	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-104	Weese, Bret	12/17/2016	11:47:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	060P	Nurses Sink Cold	NS	Lead	0.0034	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-103	Weese, Bret	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	060P	Nurses Sink Cold	NS	Copper	0.227	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-103	Weese, Bret	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	061F	Nurses Sink Hot	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-106	Weese, Bret	12/17/2016	11:49:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	061F	Nurses Sink Hot	NS	Copper	0.279	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-106	Weese, Bret	12/17/2016	11:49:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	061P	Nurses Sink Hot	NS	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-105	Weese, Bret	12/17/2016	11:48:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	061P	Nurses Sink Hot	NS	Copper	0.355	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-105	Weese, Bret	12/17/2016	11:48:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	062F	Drinking Water Bubbler Gym	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-108	Weese, Bret	12/17/2016	11:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	062F	Drinking Water Bubbler Gym	DW	Copper	0.199	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-108	Weese, Bret	12/17/2016	11:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	062P	Drinking Water Bubbler Gym	DW	Lead	0.0018	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-107	Weese, Bret	12/17/2016	11:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	062P	Drinking Water Bubbler Gym	DW	Copper	0.176	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-107	Weese, Bret	12/17/2016	11:52:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	063F	Drinking Water Bubbler Main Hall Outside Office	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-110	Weese, Bret	12/17/2016	11:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	063F	Drinking Water Bubbler Main Hall Outside Office	DW	Copper	0.0556	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-110	Weese, Bret	12/17/2016	11:50:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	063P	Drinking Water Bubbler Main Hall Outside Office	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-109	Weese, Bret	12/17/2016	11:48:00	03-Jan-17

LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	063P	Drinking Water Bubbler Main Hall Outside Office	DW	Copper	0.110	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-109	Weese, Bret	12/17/2016	11:48:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	064F	Classroom Faucet Teachers Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-112	Weese, Bret	12/17/2016	11:55:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	064F	Classroom Faucet Teachers Room	CF	Copper	0.209	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-112	Weese, Bret	12/17/2016	11:55:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	064P	Classroom Faucet Teachers Room	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-111	Weese, Bret	12/17/2016	11:54:00	03-Jan-17
LCCA	Tewksbury	02950010	Tewksbury: Heath-Brook	Public School	064P	Classroom Faucet Teachers Room	CF	Copper	0.182	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01786-111	Weese, Bret	12/17/2016	11:54:00	03-Jan-17