

Tewksbury- John F Ryan 12-17-16

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITY/TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOC ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Tewksbury	02950023	John F. Ryan	Public School	002F	Classroom Faucet Room 113	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-002	Gendron, Jamie	12/17/2016	07:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	002F	Classroom Faucet Room 113	CF	Copper	0.343	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-002	Gendron, Jamie	12/17/2016	07:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	002P	Classroom Faucet Room 113	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-001	Gendron, Jamie	12/17/2016	07:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	002P	Classroom Faucet Room 113	CF	Copper	0.354	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-001	Gendron, Jamie	12/17/2016	07:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	003F	Drinking Water Bubbler Room 115	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-004	Gendron, Jamie	12/17/2016	07:52:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	003F	Drinking Water Bubbler Room 115	DW	Copper	0.0889	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-004	Gendron, Jamie	12/17/2016	07:52:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	003P	Drinking Water Bubbler Room 115	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-003	Gendron, Jamie	12/17/2016	07:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	003P	Drinking Water Bubbler Room 115	DW	Copper	0.0969	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-003	Gendron, Jamie	12/17/2016	07:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	004F	Classroom Faucet Room 115	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-006	Gendron, Jamie	12/17/2016	07:52:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	004F	Classroom Faucet Room 115	CF	Copper	0.130	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-006	Gendron, Jamie	12/17/2016	07:52:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	004P	Classroom Faucet Room 115	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-005	Gendron, Jamie	12/17/2016	07:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	004P	Classroom Faucet Room 115	CF	Copper	0.178	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-005	Gendron, Jamie	12/17/2016	07:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	005F	Drinking Water Bubbler Room 119	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-008	Gendron, Jamie	12/17/2016	08:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	005F	Drinking Water Bubbler Room 119	DW	Copper	0.262	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-008	Gendron, Jamie	12/17/2016	08:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	005P	Drinking Water Bubbler Room 119	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-007	Gendron, Jamie	12/17/2016	08:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	005P	Drinking Water Bubbler Room 119	DW	Copper	0.210	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-007	Gendron, Jamie	12/17/2016	08:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	006F	Classroom Faucet Room 119	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-010	Gendron, Jamie	12/17/2016	08:02:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	006F	Classroom Faucet Room 119	CF	Copper	0.266	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-010	Gendron, Jamie	12/17/2016	08:02:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	006P	Classroom Faucet Room 119	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-009	Gendron, Jamie	12/17/2016	08:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	006P	Classroom Faucet Room 119	CF	Copper	0.240	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-009	Gendron, Jamie	12/17/2016	08:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	007F	Drinking Water Bubbler Room 120	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-012	Gendron, Jamie	12/17/2016	08:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	007F	Drinking Water Bubbler Room 120	DW	Copper	0.177	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-012	Gendron, Jamie	12/17/2016	08:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	007P	Drinking Water Bubbler Room 120	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-011	Gendron, Jamie	12/17/2016	08:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	007P	Drinking Water Bubbler Room 120	DW	Copper	0.115	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-011	Gendron, Jamie	12/17/2016	08:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	008F	Classroom Faucet Room 120	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-014	Gendron, Jamie	12/17/2016	08:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	008F	Classroom Faucet Room 120	CF	Copper	0.141	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-014	Gendron, Jamie	12/17/2016	08:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	008P	Classroom Faucet Room 120	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-013	Gendron, Jamie	12/17/2016	08:11:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	008P	Classroom Faucet Room 120	CF	Copper	0.235	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-013	Gendron, Jamie	12/17/2016	08:11:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	009F	Classroom Faucet Room 112	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-016	Gendron, Jamie	12/17/2016	08:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	009F	Classroom Faucet Room 112	CF	Copper	0.322	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-016	Gendron, Jamie	12/17/2016	08:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	009P	Classroom Faucet Room 112	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-015	Gendron, Jamie	12/17/2016	08:14:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	009P	Classroom Faucet Room 112	CF	Copper	0.144	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-015	Gendron, Jamie	12/17/2016	08:14:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	010F	Drinking Water Bubbler Room 112	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-018	Gendron, Jamie	12/17/2016	08:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	010F	Drinking Water Bubbler Room 112	DW	Copper	0.143	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-018	Gendron, Jamie	12/17/2016	08:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	010P	Drinking Water Bubbler Room 112	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-017	Gendron, Jamie	12/17/2016	08:16:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	010P	Drinking Water Bubbler Room 112	DW	Copper	0.230	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-017	Gendron, Jamie	12/17/2016	08:16:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	011F	Classroom Faucet Room 114	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-020	Gendron, Jamie	12/17/2016	08:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	011F	Classroom Faucet Room 114	CF	Copper	0.167	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-020	Gendron, Jamie	12/17/2016	08:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	011P	Classroom Faucet Room 114	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-019	Gendron, Jamie	12/17/2016	08:19:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	011P	Classroom Faucet Room 114	CF	Copper	0.268	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-019	Gendron, Jamie	12/17/2016	08:19:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	012F	Drinking Water Bubbler Room 114	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-022	Gendron, Jamie	12/17/2016	08:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	012F	Drinking Water Bubbler Room 114	DW	Copper	0.0662	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-022	Gendron, Jamie	12/17/2016	08:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	012P	Drinking Water Bubbler Room 114	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-021	Gendron, Jamie	12/17/2016	08:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	012P	Drinking Water Bubbler Room 114	DW	Copper	0.0971	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-021	Gendron, Jamie	12/17/2016	08:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	013F	Classroom Faucet Room 116	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-024	Gendron, Jamie	12/17/2016	08:27:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	013F	Classroom Faucet Room 116	CF	Copper	0.247	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-024	Gendron, Jamie	12/17/2016	08:27:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	013P	Classroom Faucet Room 116	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-023	Gendron, Jamie	12/17/2016	08:26:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	013P	Classroom Faucet Room 116	CF	Copper	0.213	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-023	Gendron, Jamie	12/17/2016	08:26:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	014F	Drinking Water Bubbler Room 116	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-026	Gendron, Jamie	12/17/2016	08:31:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	014F	Drinking Water Bubbler Room 116	DW	Copper	0.132	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-026	Gendron, Jamie	12/17/2016	08:31:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	014P	Drinking Water Bubbler Room 116	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-025	Gendron, Jamie	12/17/2016	08:29:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	014P	Drinking Water Bubbler Room 116	DW	Copper	0.247	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-025	Gendron, Jamie	12/17/2016	08:29:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	015F	Classroom Faucet Room 118	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-028	Gendron, Jamie	12/17/2016	08:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	015F	Classroom Faucet Room 118	CF	Copper	0.236	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-028	Gendron, Jamie	12/17/2016	08:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	015P	Classroom Faucet Room 118	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-027	Gendron, Jamie	12/17/2016	08:33:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	015P	Classroom Faucet Room 118	CF	Copper	0.412	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-027	Gendron, Jamie	12/17/2016	08:33:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	016F	Nurses Sink Cold	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-030	Gendron, Jamie	12/17/2016	08:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	016F	Nurses Sink Cold	NS	Copper	0.166	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-030	Gendron, Jamie	12/17/2016	08:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	016P	Nurses Sink Cold	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-029	Gendron, Jamie	12/17/2016	08:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	016P	Nurses Sink Cold	NS	Copper	0.287	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-029	Gendron, Jamie	12/17/2016	08:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	017F	Classroom Faucet Room 121	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-032	Gendron, Jamie	12/17/2016	08:44:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	017F	Classroom Faucet Room 121	CF	Copper	0.189	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-032	Gendron, Jamie	12/17/2016	08:44:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	017P	Classroom Faucet Room 121	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-031	Gendron, Jamie	12/17/2016	08:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	017P	Classroom Faucet Room 121	CF	Copper	0.266	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-031	Gendron, Jamie	12/17/2016	08:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	018F	Drinking Water Bubbler Room 121	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-034	Gendron, Jamie	12/17/2016	08:48:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	018F	Drinking Water Bubbler Room 121	DW	Copper	0.106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-034	Gendron, Jamie	12/17/2016	08:48:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	018P	Drinking Water Bubbler Room 121	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-033	Gendron, Jamie	12/17/2016	08:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	018P	Drinking Water Bubbler Room 121	DW	Copper	0.216	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-033	Gendron, Jamie	12/17/2016	08:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	019F	Drinking Water Bubbler Room 122	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-036	Gendron, Jamie	12/17/2016	08:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	019F	Drinking Water Bubbler Room 122	DW	Copper	0.296	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-036	Gendron, Jamie	12/17/2016	08:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	019P	Drinking Water Bubbler Room 122	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-035	Gendron, Jamie	12/17/2016	08:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	019P	Drinking Water Bubbler Room 122	DW	Copper	0.400	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-035	Gendron, Jamie	12/17/2016	08:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	020F	Classroom Faucet Room 122	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-038	Gendron, Jamie	12/17/2016	08:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	020F	Classroom Faucet Room 122	CF	Copper	0.142	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-038	Gendron, Jamie	12/17/2016	08:57:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	020P	Classroom Faucet Room 122	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-037	Gendron, Jamie	12/17/2016	08:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	020P	Classroom Faucet Room 122	CF	Copper	0.395	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-037	Gendron, Jamie	12/17/2016	08:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	021F	Classroom Faucet Room 101	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-040	Gendron, Jamie	12/17/2016	09:02:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	021F	Classroom Faucet Room 101	CF	Copper	0.203	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-040	Gendron, Jamie	12/17/2016	09:02:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	021P	Classroom Faucet Room 101	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-039	Gendron, Jamie	12/17/2016	09:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	021P	Classroom Faucet Room 101	CF	Copper	0.231	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-039	Gendron, Jamie	12/17/2016	09:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	022F	Drinking Water Bubbler Room 101	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-042	Gendron, Jamie	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	022F	Drinking Water Bubbler Room 101	DW	Copper	0.142	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-042	Gendron, Jamie	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	022P	Drinking Water Bubbler Room 101	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-041	Gendron, Jamie	12/17/2016	09:04:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	022P	Drinking Water Bubbler Room 101	DW	Copper	0.213	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-041	Gendron, Jamie	12/17/2016	09:04:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	023F	Classroom Faucet Room 102	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-044	Gendron, Jamie	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	023F	Classroom Faucet Room 102	CF	Copper	0.243	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-044	Gendron, Jamie	12/17/2016	09:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	023P	Classroom Faucet Room 102	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-043	Gendron, Jamie	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	023P	Classroom Faucet Room 102	CF	Copper	0.214	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-043	Gendron, Jamie	12/17/2016	09:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	024F	Drinking Water Bubbler Room 102	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-046	Gendron, Jamie	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	024F	Drinking Water Bubbler Room 102	DW	Copper	0.180	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-046	Gendron, Jamie	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	024P	Drinking Water Bubbler Room 102	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-045	Gendron, Jamie	12/17/2016	09:10:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	024P	Drinking Water Bubbler Room 102	DW	Copper	0.280	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-045	Gendron, Jamie	12/17/2016	09:10:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	025F	Drinking Water Bubbler Room 103	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-048	Gendron, Jamie	12/17/2016	09:14:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	025F	Drinking Water Bubbler Room 103	DW	Copper	0.117	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-048	Gendron, Jamie	12/17/2016	09:14:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	025P	Drinking Water Bubbler Room 103	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-047	Gendron, Jamie	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	025P	Drinking Water Bubbler Room 103	DW	Copper	0.197	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-047	Gendron, Jamie	12/17/2016	09:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	026F	Classroom Faucet Room 103	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-050	Gendron, Jamie	12/17/2016	09:18:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	026F	Classroom Faucet Room 103	CF	Copper	0.0780	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-050	Gendron, Jamie	12/17/2016	09:18:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	026P	Classroom Faucet Room 103	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-049	Gendron, Jamie	12/17/2016	09:16:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	026P	Classroom Faucet Room 103	CF	Copper	0.122	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-049	Gendron, Jamie	12/17/2016	09:16:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	027F	Drinking Water Bubbler Room 105	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-052	Gendron, Jamie	12/17/2016	09:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	027F	Drinking Water Bubbler Room 105	DW	Copper	0.252	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-052	Gendron, Jamie	12/17/2016	09:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	027P	Drinking Water Bubbler Room 105	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-051	Gendron, Jamie	12/17/2016	09:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	027P	Drinking Water Bubbler Room 105	DW	Copper	0.377	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-051	Gendron, Jamie	12/17/2016	09:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	028F	Classroom Faucet Room 105	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-054	Gendron, Jamie	12/17/2016	09:26:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	028F	Classroom Faucet Room 105	CF	Copper	0.205	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-054	Gendron, Jamie	12/17/2016	09:26:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	028P	Classroom Faucet Room 105	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-053	Gendron, Jamie	12/17/2016	09:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	028P	Classroom Faucet Room 105	CF	Copper	0.252	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-053	Gendron, Jamie	12/17/2016	09:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	029F	Drinking Water Bubbler Room 109	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-056	Gendron, Jamie	12/17/2016	09:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	029F	Drinking Water Bubbler Room 109	DW	Copper	0.234	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-056	Gendron, Jamie	12/17/2016	09:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	029P	Drinking Water Bubbler Room 109	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-055	Gendron, Jamie	12/17/2016	09:28:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	029P	Drinking Water Bubbler Room 109	DW	Copper	0.273	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-055	Gendron, Jamie	12/17/2016	09:28:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	030F	Classroom Faucet Room 109	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-058	Gendron, Jamie	12/17/2016	09:34:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	030F	Classroom Faucet Room 109	CF	Copper	0.0905	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-058	Gendron, Jamie	12/17/2016	09:34:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	030P	Classroom Faucet Room 109	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-057	Gendron, Jamie	12/17/2016	09:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	030P	Classroom Faucet Room 109	CF	Copper	0.130	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-057	Gendron, Jamie	12/17/2016	09:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	031F	Drinking Water Bubbler Room 111	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-060	Gendron, Jamie	12/17/2016	09:36:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	031F	Drinking Water Bubbler Room 111	DW	Copper	0.152	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-060	Gendron, Jamie	12/17/2016	09:36:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	031P	Drinking Water Bubbler Room 111	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-059	Gendron, Jamie	12/17/2016	09:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	031P	Drinking Water Bubbler Room 111	DW	Copper	0.226	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-059	Gendron, Jamie	12/17/2016	09:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	032F	Classroom Faucet Room 111	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-062	Gendron, Jamie	12/17/2016	09:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	032F	Classroom Faucet Room 111	CF	Copper	0.0703	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-062	Gendron, Jamie	12/17/2016	09:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	032P	Classroom Faucet Room 111	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-061	Gendron, Jamie	12/17/2016	09:38:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	032P	Classroom Faucet Room 111	CF	Copper	0.0846	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-061	Gendron, Jamie	12/17/2016	09:38:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	033F	Classroom Faucet Art Storage	CF	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-064	Gendron, Jamie	12/17/2016	09:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	033F	Classroom Faucet Art Storage	CF	Copper	0.114	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-064	Gendron, Jamie	12/17/2016	09:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	033P	Classroom Faucet Art Storage	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-063	Gendron, Jamie	12/17/2016	09:41:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	033P	Classroom Faucet Art Storage	CF	Copper	0.165	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-063	Gendron, Jamie	12/17/2016	09:41:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	034F	Classroom Faucet Art Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-066	Gendron, Jamie	12/17/2016	09:44:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	034F	Classroom Faucet Art Room	CF	Copper	0.198	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-066	Gendron, Jamie	12/17/2016	09:44:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	034P	Classroom Faucet Art Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-065	Gendron, Jamie	12/17/2016	09:43:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	034P	Classroom Faucet Art Room	CF	Copper	0.161	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-065	Gendron, Jamie	12/17/2016	09:43:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	035F	Water Cooler Gym	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-068	Gendron, Jamie	12/17/2016	09:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	035F	Water Cooler Gym	WC	Copper	0.194	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-068	Gendron, Jamie	12/17/2016	09:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	035P	Water Cooler Gym	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-067	Gendron, Jamie	12/17/2016	09:50:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	035P	Water Cooler Gym	WC	Copper	0.173	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-067	Gendron, Jamie	12/17/2016	09:50:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	036F	Classroom Faucet Art Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-070	Gendron, Jamie	12/17/2016	09:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	036F	Classroom Faucet Art Room	CF	Copper	0.164	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-070	Gendron, Jamie	12/17/2016	09:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	036P	Classroom Faucet Art Room	CF	Lead	0.0034	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-069	Gendron, Jamie	12/17/2016	09:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	036P	Classroom Faucet Art Room	CF	Copper	0.576	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-069	Gendron, Jamie	12/17/2016	09:46:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	037F	Classroom Faucet Art Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-072	Gendron, Jamie	12/17/2016	09:48:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	037F	Classroom Faucet Art Room	CF	Copper	0.164	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-072	Gendron, Jamie	12/17/2016	09:48:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	037P	Classroom Faucet Art Room	CF	Lead	0.0376	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-071	Gendron, Jamie	12/17/2016	09:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	037P	Classroom Faucet Art Room	CF	Copper	2.13	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-071	Gendron, Jamie	12/17/2016	09:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	038F	Classroom Faucet Music Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-074	Gendron, Jamie	12/17/2016	09:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	038F	Classroom Faucet Music Room	CF	Copper	0.416	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-074	Gendron, Jamie	12/17/2016	09:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	038P	Classroom Faucet Music Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-073	Gendron, Jamie	12/17/2016	09:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	038P	Classroom Faucet Music Room	CF	Copper	0.355	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-073	Gendron, Jamie	12/17/2016	09:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	039F	Drinking Water Bubbler Room 110	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-076	Gendron, Jamie	12/17/2016	09:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	039F	Drinking Water Bubbler Room 110	DW	Copper	0.0839	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-076	Gendron, Jamie	12/17/2016	09:57:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	039P	Drinking Water Bubbler Room 110	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-075	Gendron, Jamie	12/17/2016	09:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	039P	Drinking Water Bubbler Room 110	DW	Copper	0.0929	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-075	Gendron, Jamie	12/17/2016	09:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	040F	Classroom Faucet Room 110	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-078	Gendron, Jamie	12/17/2016	10:01:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	040F	Classroom Faucet Room 110	CF	Copper	0.251	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-078	Gendron, Jamie	12/17/2016	10:01:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	040P	Classroom Faucet Room 110	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-077	Gendron, Jamie	12/17/2016	09:59:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	040P	Classroom Faucet Room 110	CF	Copper	0.187	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-077	Gendron, Jamie	12/17/2016	09:59:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	041F	Drinking Water Bubbler Room 108	DW	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-080	Gendron, Jamie	12/17/2016	10:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	041F	Drinking Water Bubbler Room 108	DW	Copper	0.245	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-080	Gendron, Jamie	12/17/2016	10:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	041P	Drinking Water Bubbler Room 108	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-079	Gendron, Jamie	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	041P	Drinking Water Bubbler Room 108	DW	Copper	0.256	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-079	Gendron, Jamie	12/17/2016	10:03:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	042F	Classroom Faucet Room 108	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-082	Gendron, Jamie	12/17/2016	10:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	042F	Classroom Faucet Room 108	CF	Copper	0.203	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-082	Gendron, Jamie	12/17/2016	10:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	042P	Classroom Faucet Room 108	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-081	Gendron, Jamie	12/17/2016	10:07:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	042P	Classroom Faucet Room 108	CF	Copper	0.232	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-081	Gendron, Jamie	12/17/2016	10:07:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	043F	Drinking Water Bubbler Room 106	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-084	Gendron, Jamie	12/17/2016	10:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	043F	Drinking Water Bubbler Room 106	DW	Copper	0.157	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-084	Gendron, Jamie	12/17/2016	10:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	043P	Drinking Water Bubbler Room 106	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-083	Gendron, Jamie	12/17/2016	10:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	043P	Drinking Water Bubbler Room 106	DW	Copper	0.154	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-083	Gendron, Jamie	12/17/2016	10:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	044F	Classroom Faucet Room 106	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-086	Gendron, Jamie	12/17/2016	10:11:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	044F	Classroom Faucet Room 106	CF	Copper	0.309	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-086	Gendron, Jamie	12/17/2016	10:11:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	044P	Classroom Faucet Room 106	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-085	Gendron, Jamie	12/17/2016	10:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	044P	Classroom Faucet Room 106	CF	Copper	0.248	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-085	Gendron, Jamie	12/17/2016	10:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	045F	Drinking Water Bubbler Room 104	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-088	Gendron, Jamie	12/17/2016	10:19:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	045F	Drinking Water Bubbler Room 104	DW	Copper	0.195	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-088	Gendron, Jamie	12/17/2016	10:19:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	045P	Drinking Water Bubbler Room 104	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-087	Gendron, Jamie	12/17/2016	10:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	045P	Drinking Water Bubbler Room 104	DW	Copper	0.195	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-087	Gendron, Jamie	12/17/2016	10:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	046F	Classroom Faucet Room 104	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-090	Gendron, Jamie	12/17/2016	10:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	046F	Classroom Faucet Room 104	CF	Copper	0.162	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-090	Gendron, Jamie	12/17/2016	10:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	046P	Classroom Faucet Room 104	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-089	Gendron, Jamie	12/17/2016	10:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	046P	Classroom Faucet Room 104	CF	Copper	0.228	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-089	Gendron, Jamie	12/17/2016	10:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	047F	Classroom Faucet Room 213	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-092	Gendron, Jamie	12/17/2016	10:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	047F	Classroom Faucet Room 213	CF	Copper	0.388	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-092	Gendron, Jamie	12/17/2016	10:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	047P	Classroom Faucet Room 213	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-091	Gendron, Jamie	12/17/2016	10:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	047P	Classroom Faucet Room 213	CF	Copper	0.599	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-091	Gendron, Jamie	12/17/2016	10:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	048F	Drinking Water Bubbler Room 215	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-094	Gendron, Jamie	12/17/2016	10:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	048F	Drinking Water Bubbler Room 215	DW	Copper	0.130	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-094	Gendron, Jamie	12/17/2016	10:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	048P	Drinking Water Bubbler Room 215	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-093	Gendron, Jamie	12/17/2016	10:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	048P	Drinking Water Bubbler Room 215	DW	Copper	0.425	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-093	Gendron, Jamie	12/17/2016	10:21:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	049F	Classroom Faucet Room 215	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-096	Gendron, Jamie	12/17/2016	10:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	049F	Classroom Faucet Room 215	CF	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-096	Gendron, Jamie	12/17/2016	10:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	049P	Classroom Faucet Room 215	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-095	Gendron, Jamie	12/17/2016	10:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	049P	Classroom Faucet Room 215	CF	Copper	0.147	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-095	Gendron, Jamie	12/17/2016	10:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	050F	Drinking Water Bubbler Room 219	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-098	Gendron, Jamie	12/17/2016	10:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	050F	Drinking Water Bubbler Room 219	DW	Copper	0.130	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-098	Gendron, Jamie	12/17/2016	10:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	050P	Drinking Water Bubbler Room 219	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-097	Gendron, Jamie	12/17/2016	10:28:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	050P	Drinking Water Bubbler Room 219	DW	Copper	0.122	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-097	Gendron, Jamie	12/17/2016	10:28:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	051F	Classroom Faucet Room 219	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-100	Gendron, Jamie	12/17/2016	10:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	051F	Classroom Faucet Room 219	CF	Copper	0.263	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-100	Gendron, Jamie	12/17/2016	10:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	051P	Classroom Faucet Room 219	CF	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-099	Gendron, Jamie	12/17/2016	10:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	051P	Classroom Faucet Room 219	CF	Copper	0.400	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-099	Gendron, Jamie	12/17/2016	10:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	052F	Drinking Water Bubbler Room 220	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-102	Gendron, Jamie	12/17/2016	10:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	052F	Drinking Water Bubbler Room 220	DW	Copper	0.181	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-102	Gendron, Jamie	12/17/2016	10:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	052P	Drinking Water Bubbler Room 220	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-101	Gendron, Jamie	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	052P	Drinking Water Bubbler Room 220	DW	Copper	0.167	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-101	Gendron, Jamie	12/17/2016	10:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	053F	Classroom Faucet Room 220	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-104	Gendron, Jamie	12/17/2016	10:43:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	053F	Classroom Faucet Room 220	CF	Copper	0.147	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-104	Gendron, Jamie	12/17/2016	10:43:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	053P	Classroom Faucet Room 220	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-103	Gendron, Jamie	12/17/2016	10:41:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	053P	Classroom Faucet Room 220	CF	Copper	0.231	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-103	Gendron, Jamie	12/17/2016	10:41:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	054F	Classroom Faucet Room 210	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-106	Gendron, Jamie	12/17/2016	10:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	054F	Classroom Faucet Room 210	CF	Copper	0.173	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-106	Gendron, Jamie	12/17/2016	10:47:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	054P	Classroom Faucet Room 210	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-105	Gendron, Jamie	12/17/2016	10:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	054P	Classroom Faucet Room 210	CF	Copper	0.718	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-105	Gendron, Jamie	12/17/2016	10:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	055F	Drinking Water Bubbler Room 210	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-108	Gendron, Jamie	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	055F	Drinking Water Bubbler Room 210	DW	Copper	0.0682	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-108	Gendron, Jamie	12/17/2016	10:51:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	055P	Drinking Water Bubbler Room 210	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-107	Gendron, Jamie	12/17/2016	10:50:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	055P	Drinking Water Bubbler Room 210	DW	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-107	Gendron, Jamie	12/17/2016	10:50:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	056F	Classroom Faucet Room 214	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-110	Gendron, Jamie	12/17/2016	10:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	056F	Classroom Faucet Room 214	CF	Copper	0.154	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-110	Gendron, Jamie	12/17/2016	10:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	056P	Classroom Faucet Room 214	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-109	Gendron, Jamie	12/17/2016	10:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	056P	Classroom Faucet Room 214	CF	Copper	0.164	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-109	Gendron, Jamie	12/17/2016	10:53:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	057F	Drinking Water Bubbler Room 214	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-112	Gendron, Jamie	12/17/2016	10:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	057F	Drinking Water Bubbler Room 214	DW	Copper	0.0652	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-112	Gendron, Jamie	12/17/2016	10:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	057P	Drinking Water Bubbler Room 214	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-111	Gendron, Jamie	12/17/2016	10:56:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	057P	Drinking Water Bubbler Room 214	DW	Copper	0.106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-111	Gendron, Jamie	12/17/2016	10:56:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	058F	Classroom Faucet Room 216	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-114	Gendron, Jamie	12/17/2016	10:59:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	058F	Classroom Faucet Room 216	CF	Copper	0.199	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-114	Gendron, Jamie	12/17/2016	10:59:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	058P	Classroom Faucet Room 216	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-113	Gendron, Jamie	12/17/2016	10:58:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	058P	Classroom Faucet Room 216	CF	Copper	0.198	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-113	Gendron, Jamie	12/17/2016	10:58:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	059F	Drinking Water Bubbler Room 216	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-116	Gendron, Jamie	12/17/2016	11:01:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	059F	Drinking Water Bubbler Room 216	DW	Copper	0.104	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-116	Gendron, Jamie	12/17/2016	11:01:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	059P	Drinking Water Bubbler Room 216	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-115	Gendron, Jamie	12/17/2016	11:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	059P	Drinking Water Bubbler Room 216	DW	Copper	0.282	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-115	Gendron, Jamie	12/17/2016	11:00:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	060F	Classroom Faucet Room 218	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-118	Gendron, Jamie	12/17/2016	11:03:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	060F	Classroom Faucet Room 218	CF	Copper	0.301	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-118	Gendron, Jamie	12/17/2016	11:03:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	060P	Classroom Faucet Room 218	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-117	Gendron, Jamie	12/17/2016	11:02:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	060P	Classroom Faucet Room 218	CF	Copper	0.302	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-117	Gendron, Jamie	12/17/2016	11:02:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	061F	Drinking Water Bubbler Room Health Room	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-120	Gendron, Jamie	12/17/2016	11:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	061F	Drinking Water Bubbler Room Health Room	DW	Copper	0.206	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-120	Gendron, Jamie	12/17/2016	11:06:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	061P	Drinking Water Bubbler Room Health Room	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-119	Gendron, Jamie	12/17/2016	11:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	061P	Drinking Water Bubbler Room Health Room	DW	Copper	0.249	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-119	Gendron, Jamie	12/17/2016	11:05:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	062F	Classroom Faucet Health Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-122	Gendron, Jamie	12/17/2016	11:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	062F	Classroom Faucet Health Room	CF	Copper	0.121	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-122	Gendron, Jamie	12/17/2016	11:08:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	062P	Classroom Faucet Health Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-121	Gendron, Jamie	12/17/2016	11:07:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	062P	Classroom Faucet Health Room	CF	Copper	0.375	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-121	Gendron, Jamie	12/17/2016	11:07:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	063F	Drinking Water Bubbler Health / World Language Roo	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-124	Gendron, Jamie	12/17/2016	11:10:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	063F	Drinking Water Bubbler Health / World Language Roo	DW	Copper	0.131	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-124	Gendron, Jamie	12/17/2016	11:10:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	063P	Drinking Water Bubbler Health / World Language Roo	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-123	Gendron, Jamie	12/17/2016	11:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	063P	Drinking Water Bubbler Health / World Language Roo	DW	Copper	0.263	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-123	Gendron, Jamie	12/17/2016	11:09:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	064F	Classroom Faucet Health / World Language Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-126	Gendron, Jamie	12/17/2016	11:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	064F	Classroom Faucet Health / World Language Room	CF	Copper	0.194	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-126	Gendron, Jamie	12/17/2016	11:12:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	064P	Classroom Faucet Health / World Language Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-125	Gendron, Jamie	12/17/2016	11:11:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	064P	Classroom Faucet Health / World Language Room	CF	Copper	0.226	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-125	Gendron, Jamie	12/17/2016	11:11:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	065F	Drinking Water Bubbler Room 203	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-128	Gendron, Jamie	12/17/2016	11:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	065F	Drinking Water Bubbler Room 203	DW	Copper	0.104	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-128	Gendron, Jamie	12/17/2016	11:15:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	065P	Drinking Water Bubbler Room 203	DW	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-127	Gendron, Jamie	12/17/2016	11:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	065P	Drinking Water Bubbler Room 203	DW	Copper	0.152	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-127	Gendron, Jamie	12/17/2016	11:13:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	066F	Classroom Faucet Room 203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-130	Gendron, Jamie	12/17/2016	11:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	066F	Classroom Faucet Room 203	CF	Copper	0.188	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-130	Gendron, Jamie	12/17/2016	11:17:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	066P	Classroom Faucet Room 203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-129	Gendron, Jamie	12/17/2016	11:16:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	066P	Classroom Faucet Room 203	CF	Copper	0.287	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-129	Gendron, Jamie	12/17/2016	11:16:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	067F	Drinking Water Bubbler Room 205	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-132	Gendron, Jamie	12/17/2016	11:19:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	067F	Drinking Water Bubbler Room 205	DW	Copper	0.231	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-132	Gendron, Jamie	12/17/2016	11:19:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	067P	Drinking Water Bubbler Room 205	DW	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-131	Gendron, Jamie	12/17/2016	11:18:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	067P	Drinking Water Bubbler Room 205	DW	Copper	0.141	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-131	Gendron, Jamie	12/17/2016	11:18:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	068F	Classroom Faucet Room 205	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-134	Gendron, Jamie	12/17/2016	11:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	068F	Classroom Faucet Room 205	CF	Copper	0.235	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-134	Gendron, Jamie	12/17/2016	11:21:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	068P	Classroom Faucet Room 205	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-133	Gendron, Jamie	12/17/2016	11:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	068P	Classroom Faucet Room 205	CF	Copper	0.252	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-133	Gendron, Jamie	12/17/2016	11:20:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	069F	Drinking Water Bubbler Room 209	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-136	Gendron, Jamie	12/17/2016	11:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	069F	Drinking Water Bubbler Room 209	DW	Copper	0.172	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-136	Gendron, Jamie	12/17/2016	11:23:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	069P	Drinking Water Bubbler Room 209	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-135	Gendron, Jamie	12/17/2016	11:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	069P	Drinking Water Bubbler Room 209	DW	Copper	0.218	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-135	Gendron, Jamie	12/17/2016	11:22:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	070F	Classroom Faucet Room 209	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-138	Gendron, Jamie	12/17/2016	11:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	070F	Classroom Faucet Room 209	CF	Copper	0.216	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-138	Gendron, Jamie	12/17/2016	11:24:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	070P	Classroom Faucet Room 209	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-137	Gendron, Jamie	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	070P	Classroom Faucet Room 209	CF	Copper	0.197	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-137	Gendron, Jamie	12/17/2016	11:25:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	071F	Drinking Water Bubbler Room 211	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-140	Gendron, Jamie	12/17/2016	11:27:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	071F	Drinking Water Bubbler Room 211	DW	Copper	0.110	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-140	Gendron, Jamie	12/17/2016	11:27:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	071P	Drinking Water Bubbler Room 211	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-139	Gendron, Jamie	12/17/2016	11:26:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	071P	Drinking Water Bubbler Room 211	DW	Copper	0.190	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-139	Gendron, Jamie	12/17/2016	11:26:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	072F	Classroom Faucet Room 211	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-142	Gendron, Jamie	12/17/2016	11:29:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	072F	Classroom Faucet Room 211	CF	Copper	0.201	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-142	Gendron, Jamie	12/17/2016	11:29:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	072P	Classroom Faucet Room 211	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-141	Gendron, Jamie	12/17/2016	11:28:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	072P	Classroom Faucet Room 211	CF	Copper	0.436	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-141	Gendron, Jamie	12/17/2016	11:28:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	073F	Drinking Water Bubbler Room 210	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-144	Gendron, Jamie	12/17/2016	11:31:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	073F	Drinking Water Bubbler Room 210	DW	Copper	0.0740	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-144	Gendron, Jamie	12/17/2016	11:31:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	073P	Drinking Water Bubbler Room 210	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-143	Gendron, Jamie	12/17/2016	11:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	073P	Drinking Water Bubbler Room 210	DW	Copper	0.175	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-143	Gendron, Jamie	12/17/2016	11:30:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	074F	Classroom Faucet Room 210	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-146	Gendron, Jamie	12/17/2016	11:33:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	074F	Classroom Faucet Room 210	CF	Copper	0.149	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-146	Gendron, Jamie	12/17/2016	11:33:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	074P	Classroom Faucet Room 210	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-145	Gendron, Jamie	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	074P	Classroom Faucet Room 210	CF	Copper	0.238	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-145	Gendron, Jamie	12/17/2016	11:32:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	075F	Drinking Water Bubbler Room 208	DW	Lead	0.0025	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-148	Gendron, Jamie	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	075F	Drinking Water Bubbler Room 208	DW	Copper	0.404	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-148	Gendron, Jamie	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	075P	Drinking Water Bubbler Room 208	DW	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-147	Gendron, Jamie	12/17/2016	11:36:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	075P	Drinking Water Bubbler Room 208	DW	Copper	0.202	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-147	Gendron, Jamie	12/17/2016	11:36:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	076F	Drinking Water Bubbler Room 206	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-150	Gendron, Jamie	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	076F	Drinking Water Bubbler Room 206	DW	Copper	0.413	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-150	Gendron, Jamie	12/17/2016	11:37:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	076P	Drinking Water Bubbler Room 206	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-149	Gendron, Jamie	12/17/2016	11:36:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	076P	Drinking Water Bubbler Room 206	DW	Copper	0.257	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-149	Gendron, Jamie	12/17/2016	11:36:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	077F	Classroom Faucet Room 206	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-152	Gendron, Jamie	12/17/2016	11:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	077F	Classroom Faucet Room 206	CF	Copper	0.262	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-152	Gendron, Jamie	12/17/2016	11:39:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	077P	Classroom Faucet Room 206	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-151	Gendron, Jamie	12/17/2016	11:38:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	077P	Classroom Faucet Room 206	CF	Copper	0.261	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-151	Gendron, Jamie	12/17/2016	11:38:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	078F	Drinking Water Bubbler Room 204	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-154	Gendron, Jamie	12/17/2016	11:41:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	078F	Drinking Water Bubbler Room 204	DW	Copper	0.239	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-154	Gendron, Jamie	12/17/2016	11:41:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	078P	Drinking Water Bubbler Room 204	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-153	Gendron, Jamie	12/17/2016	11:40:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	078P	Drinking Water Bubbler Room 204	DW	Copper	0.200	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-153	Gendron, Jamie	12/17/2016	11:40:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	079F	Classroom Faucet Room 204	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-156	Gendron, Jamie	12/17/2016	11:43:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	079F	Classroom Faucet Room 204	CF	Copper	0.178	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-156	Gendron, Jamie	12/17/2016	11:43:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	079P	Classroom Faucet Room 204	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-155	Gendron, Jamie	12/17/2016	11:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	079P	Classroom Faucet Room 204	CF	Copper	0.201	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-155	Gendron, Jamie	12/17/2016	11:42:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	080F	Classroom Faucet Library	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-158	Gendron, Jamie	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	080F	Classroom Faucet Library	CF	Copper	0.302	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-158	Gendron, Jamie	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	080P	Classroom Faucet Library	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-157	Gendron, Jamie	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	080P	Classroom Faucet Library	CF	Copper	0.208	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-157	Gendron, Jamie	12/17/2016	11:45:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	081F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-160	Gendron, Jamie	12/17/2016	11:58:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	081F	Kitchen Faucet Cold	KC	Copper	0.161	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-160	Gendron, Jamie	12/17/2016	11:58:00	03-Jan-17

Tewksbury- John F Ryan 12-17-16

LCCA	Tewksbury	02950023	John F. Ryan	Public School	081P	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-159	Gendron, Jamie	12/17/2016	11:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	081P	Kitchen Faucet Cold	KC	Copper	0.193	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-159	Gendron, Jamie	12/17/2016	11:55:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	082F	Kitchen Kettle Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-162	Gendron, Jamie	12/17/2016	11:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	082F	Kitchen Kettle Hot	KC	Copper	0.132	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-162	Gendron, Jamie	12/17/2016	11:57:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	082P	Kitchen Kettle Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-161	Gendron, Jamie	12/17/2016	11:56:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	082P	Kitchen Kettle Hot	KC	Copper	0.115	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-161	Gendron, Jamie	12/17/2016	11:56:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	083F	Classroom Faucet Room 208	CF	Lead	0.0010	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-164	Gendron, Jamie	12/17/2016	11:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	083F	Classroom Faucet Room 208	CF	Copper	0.222	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-164	Gendron, Jamie	12/17/2016	11:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	083P	Classroom Faucet Room 208	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-163	Gendron, Jamie	12/17/2016	11:35:00	03-Jan-17
LCCA	Tewksbury	02950023	John F. Ryan	Public School	083P	Classroom Faucet Room 208	CF	Copper	0.151	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01840-163	Gendron, Jamie	12/17/2016	11:35:00	03-Jan-17