

Tewksbury- John W. Wynn Middle 11-19-2016

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

| REPORT TYPE CODE | TOWN | ORG CODE | SCHOOL NAME | SCHOOL TYPE | LOC ID | SAMPLE LOCATION NAME | SAMPLE COMMENTS | ANALYTE NAME | RESULT | UNITS OF MEAS | METHOD DETECTION LIMIT | ANALYTICAL METHOD USED | ANALYSIS LAB | LAB SAMPLE ID | ANALYSIS COMMENTS | SAMPLER NAME | SAMPLE COLLECTION DATE | SAMPLE COLLECTION TIME | REPORT DATE |
|------------------|-----------|----------|--------------------------------|---------------|--------|---|-----------------|--------------|--------|---------------|------------------------|------------------------|---------------------------------------|----------------|-------------------|--------------|------------------------|------------------------|-------------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 001F | Water Cooler / Outside Alternative Class | WC | Copper | 0.388 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-002 | | Carter, Dan | 11/19/2016 | 11:57:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 001F | Water Cooler / Outside Alternative Class | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-002 | | Carter, Dan | 11/19/2016 | 11:57:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 001P | Water Cooler / Outside Alternative Class | WC | Copper | 0.388 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-001 | | Carter, Dan | 11/19/2016 | 11:55:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 001P | Water Cooler / Outside Alternative Class | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-001 | | Carter, Dan | 11/19/2016 | 11:55:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 002F | Drinking Water Bubblers Outside Locker Room | DW | Copper | 0.135 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-004 | | Carter, Dan | 11/19/2016 | 12:03:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 002F | Drinking Water Bubblers Outside Locker Room | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-004 | | Carter, Dan | 11/19/2016 | 12:03:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 002P | Drinking Water Bubblers Outside Locker Room | DW | Copper | 0.178 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-003 | | Carter, Dan | 11/19/2016 | 12:02:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 002P | Drinking Water Bubblers Outside Locker Room | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-003 | | Carter, Dan | 11/19/2016 | 12:02:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 003F | Drinking Water Bubblers Outside Locker Room | DW | Copper | 0.139 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-006 | | Carter, Dan | 11/19/2016 | 12:04:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 003F | Drinking Water Bubblers Outside Locker Room | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-006 | | Carter, Dan | 11/19/2016 | 12:04:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 003P | Drinking Water Bubblers Outside Locker Room | DW | Copper | 0.182 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-005 | | Carter, Dan | 11/19/2016 | 12:02:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|--|----|--------|--------|------|-------|-----------|--|----------------|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 003P | Drinking Water Bubbler Outside Locker Room | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-005 | Carter, Dan | 11/19/2016 | 12:02:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 004F | Drinking Water Bubbler Inside Gym | DW | Copper | 0.214 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-008 | Carter, Dan | 11/19/2016 | 11:54:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 004F | Drinking Water Bubbler Inside Gym | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-008 | Carter, Dan | 11/19/2016 | 11:54:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 004P | Drinking Water Bubbler Inside Gym | DW | Copper | 0.270 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-007 | Carter, Dan | 11/19/2016 | 11:51:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 004P | Drinking Water Bubbler Inside Gym | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-007 | Carter, Dan | 11/19/2016 | 11:51:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 005F | Classroom Faucet Inside Weight Room | CF | Copper | 0.392 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-010 | Carter, Dan | 11/19/2016 | 12:09:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 005F | Classroom Faucet Inside Weight Room | CF | Lead | 0.0084 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-010 | Carter, Dan | 11/19/2016 | 12:09:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 005P | Classroom Faucet Inside Weight Room | CF | Copper | 0.501 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-009 | Carter, Dan | 11/19/2016 | 12:07:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 005P | Classroom Faucet Inside Weight Room | CF | Lead | 0.0160 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-009 | Carter, Dan | 11/19/2016 | 12:07:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 006F | Kitchen Kettle Cold | KK | Copper | 0.506 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-012 | Carter, Dan | 11/19/2016 | 12:24:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 006F | Kitchen Kettle Cold | KK | Lead | 0.0054 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-012 | Carter, Dan | 11/19/2016 | 12:24:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 006P | Kitchen Kettle Cold | KK | Copper | 0.344 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-011 | Carter, Dan | 11/19/2016 | 12:22:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 006P | Kitchen Kettle Cold | KK | Lead | 0.0237 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-011 | Carter, Dan | 11/19/2016 | 12:22:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 007F | Kitchen Kettle Hot | KK | Copper | 4.23 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-014 | Carter, Dan | 11/19/2016 | 12:24:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 007F | Kitchen Kettle Hot | KK | Lead | 0.0188 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-014 | Carter, Dan | 11/19/2016 | 12:24:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|-----------------------------------|----|--------|--------|------|-------|-----------|--|----------------|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 007P | Kitchen Kettle Hot | KK | Copper | 0.825 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-013 | | Carter, Dan | 11/19/2016 | 12:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 007P | Kitchen Kettle Hot | KK | Lead | 0.0346 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-013 | | Carter, Dan | 11/19/2016 | 12:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 008F | Kitchen Faucet Cold | KC | Copper | 0.0953 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-016 | | Carter, Dan | 11/19/2016 | 12:18:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 008F | Kitchen Faucet Cold | KC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-016 | | Carter, Dan | 11/19/2016 | 12:18:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 008P | Kitchen Faucet Cold | KC | Copper | 0.197 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-015 | | Carter, Dan | 11/19/2016 | 12:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 008P | Kitchen Faucet Cold | KC | Lead | 0.0017 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-015 | | Carter, Dan | 11/19/2016 | 12:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 009F | Kitchen Faucet Hot | KC | Copper | 0.177 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-018 | | Carter, Dan | 11/19/2016 | 12:18:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 009F | Kitchen Faucet Hot | KC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-018 | | Carter, Dan | 11/19/2016 | 12:18:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 009P | Kitchen Faucet Hot | KC | Copper | 0.230 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-017 | | Carter, Dan | 11/19/2016 | 12:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 009P | Kitchen Faucet Hot | KC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-017 | | Carter, Dan | 11/19/2016 | 12:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 010F | Drinking Water Bubbler Cafe | DW | Copper | 0.489 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-020 | | Carter, Dan | 11/19/2016 | 12:33:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 010F | Drinking Water Bubbler Cafe | DW | Lead | 0.0020 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-020 | | Carter, Dan | 11/19/2016 | 12:33:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 010P | Drinking Water Bubbler Cafe | DW | Copper | 0.299 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-019 | | Carter, Dan | 11/19/2016 | 12:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 010P | Drinking Water Bubbler Cafe | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-019 | | Carter, Dan | 11/19/2016 | 12:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 011F | Drinking Water Bubbler Cafe | DW | Copper | 0.486 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-022 | | Carter, Dan | 11/19/2016 | 12:33:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|---|----|--------|--------|------|-------|-----------|--|----------------|--|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 011F | Drinking Water Bubbler Cafe | DW | Lead | 0.0019 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-022 | | | Carter, Dan | 11/19/2016 | 12:33:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 011P | Drinking Water Bubbler Cafe | DW | Copper | 0.292 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-021 | | | Carter, Dan | 11/19/2016 | 12:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 011P | Drinking Water Bubbler Cafe | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-021 | | | Carter, Dan | 11/19/2016 | 12:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 012F | Drinking Water Bubbler Outside Auditorium | DW | Copper | 0.738 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-024 | | | Carter, Dan | 11/19/2016 | 12:39:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 012F | Drinking Water Bubbler Outside Auditorium | DW | Lead | 0.0012 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-024 | | | Carter, Dan | 11/19/2016 | 12:39:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 012P | Drinking Water Bubbler Outside Auditorium | DW | Copper | 1.40 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-023 | | | Carter, Dan | 11/19/2016 | 12:37:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 012P | Drinking Water Bubbler Outside Auditorium | DW | Lead | 0.0020 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-023 | | | Carter, Dan | 11/19/2016 | 12:37:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 013F | Drinking Water Bubbler Outside Auditorium | DW | Copper | 0.718 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-026 | | | Carter, Dan | 11/19/2016 | 12:39:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 013F | Drinking Water Bubbler Outside Auditorium | DW | Lead | 0.0014 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-026 | | | Carter, Dan | 11/19/2016 | 12:39:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 013P | Drinking Water Bubbler Outside Auditorium | DW | Copper | 0.444 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-025 | | | Carter, Dan | 11/19/2016 | 12:37:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 013P | Drinking Water Bubbler Outside Auditorium | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-025 | | | Carter, Dan | 11/19/2016 | 12:37:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 014F | Nurses Sick Cold Supply | NS | Copper | 0.112 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-028 | | | Carter, Dan | 11/19/2016 | 12:47:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 014F | Nurses Sick Cold Supply | NS | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-028 | | | Carter, Dan | 11/19/2016 | 12:47:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|---|----|--------|--------|------|-------|-----------|--|----------------|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 014P | Nurses Sick Cold Supply | NS | Copper | 0.176 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-027 | | Carter, Dan | 11/19/2016 | 12:46:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 014P | Nurses Sick Cold Supply | NS | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-027 | | Carter, Dan | 11/19/2016 | 12:46:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 015F | Nurses Sink Hot Supply | NS | Copper | 0.341 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-030 | | Carter, Dan | 11/19/2016 | 12:48:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 015F | Nurses Sink Hot Supply | NS | Lead | 0.0010 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-030 | | Carter, Dan | 11/19/2016 | 12:48:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 015P | Nurses Sink Hot Supply | NS | Copper | 0.686 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-029 | | Carter, Dan | 11/19/2016 | 12:46:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 015P | Nurses Sink Hot Supply | NS | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-029 | | Carter, Dan | 11/19/2016 | 12:46:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 016F | Drinking Water Bubbler Outside Guidance | DW | Copper | 0.208 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-032 | | Carter, Dan | 11/19/2016 | 12:56:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 016F | Drinking Water Bubbler Outside Guidance | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-032 | | Carter, Dan | 11/19/2016 | 12:56:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 016P | Drinking Water Bubbler Outside Guidance | DW | Copper | 0.226 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-031 | | Carter, Dan | 11/19/2016 | 12:54:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 016P | Drinking Water Bubbler Outside Guidance | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-031 | | Carter, Dan | 11/19/2016 | 12:54:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 017F | Drinking Water Bubbler Outside Guidance | DW | Copper | 0.198 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-034 | | Carter, Dan | 11/19/2016 | 12:56:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 017F | Drinking Water Bubbler Outside Guidance | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-034 | | Carter, Dan | 11/19/2016 | 12:56:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 017P | Drinking Water Bubbler Outside Guidance | DW | Copper | 0.213 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-033 | | Carter, Dan | 11/19/2016 | 12:54:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|---|----|--------|--------|------|-------|-----------|--|----------------|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 017P | Drinking Water Bubbler Outside Guidance | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-033 | Carter, Dan | 11/19/2016 | 12:54:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 018F | Classroom Faucet Work Room in Library | CF | Copper | 0.114 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-036 | Carter, Dan | 11/19/2016 | 13:00:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 018F | Classroom Faucet Work Room in Library | CF | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-036 | Carter, Dan | 11/19/2016 | 13:00:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 018P | Classroom Faucet Work Room in Library | CF | Copper | 0.161 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-035 | Carter, Dan | 11/19/2016 | 12:59:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 018P | Classroom Faucet Work Room in Library | CF | Lead | 0.0120 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-035 | Carter, Dan | 11/19/2016 | 12:59:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 019F | Classroom Faucet Room 111 | CF | Copper | 0.100 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-038 | Carter, Dan | 11/19/2016 | 13:12:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 019F | Classroom Faucet Room 111 | CF | Lead | 0.0019 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-038 | Carter, Dan | 11/19/2016 | 13:12:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 019P | Classroom Faucet Room 111 | CF | Copper | 0.237 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-037 | Carter, Dan | 11/19/2016 | 13:10:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 019P | Classroom Faucet Room 111 | CF | Lead | 0.0089 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-037 | Carter, Dan | 11/19/2016 | 13:10:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 020F | Water Cooler Outside Elevator | WC | Copper | 0.202 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-040 | Carter, Dan | 11/19/2016 | 13:07:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 020F | Water Cooler Outside Elevator | WC | Lead | 0.0014 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-040 | Carter, Dan | 11/19/2016 | 13:07:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 020P | Water Cooler Outside Elevator | WC | Copper | 0.189 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-039 | Carter, Dan | 11/19/2016 | 13:06:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 020P | Water Cooler Outside Elevator | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-039 | Carter, Dan | 11/19/2016 | 13:06:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 021F | Water Cooler Outside Elevator | WC | Copper | 0.202 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-042 | Carter, Dan | 11/19/2016 | 13:07:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 021F | Water Cooler Outside Elevator | WC | Lead | 0.0023 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-042 | Carter, Dan | 11/19/2016 | 13:07:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|-------------------------------------|----|--------|--------|------|-------|-----------|--|----------------|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 021P | Water Cooler Outside Elevator | WC | Copper | 0.199 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-041 | | Carter, Dan | 11/19/2016 | 13:06:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 021P | Water Cooler Outside Elevator | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-041 | | Carter, Dan | 11/19/2016 | 13:06:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 022F | Water Cooler Across from 114 | WC | Copper | 0.211 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-044 | | Carter, Dan | 11/19/2016 | 13:23:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 022F | Water Cooler Across from 114 | WC | Lead | 0.0029 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-044 | | Carter, Dan | 11/19/2016 | 13:23:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 022P | Water Cooler Across from 114 | WC | Copper | 0.106 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-043 | | Carter, Dan | 11/19/2016 | 13:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 022P | Water Cooler Across from 114 | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-043 | | Carter, Dan | 11/19/2016 | 13:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 023F | Water Cooler Across from 114 | WC | Copper | 0.207 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-046 | | Carter, Dan | 11/19/2016 | 13:23:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 023F | Water Cooler Across from 114 | WC | Lead | 0.0027 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-046 | | Carter, Dan | 11/19/2016 | 13:23:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 023P | Water Cooler Across from 114 | WC | Copper | 0.139 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-045 | | Carter, Dan | 11/19/2016 | 13:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 023P | Water Cooler Across from 114 | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-045 | | Carter, Dan | 11/19/2016 | 13:21:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 024F | Home Economics Hot | EC | Copper | 0.242 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-048 | | Carter, Dan | 11/19/2016 | 13:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 024F | Home Economics Hot | EC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-048 | | Carter, Dan | 11/19/2016 | 13:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 024P | Home Economics Hot | EC | Copper | 0.751 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-047 | | Carter, Dan | 11/19/2016 | 13:14:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 024P | Home Economics Hot | EC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-047 | | Carter, Dan | 11/19/2016 | 13:14:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 025F | Home Economics Cold | EC | Copper | 0.0720 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-050 | | Carter, Dan | 11/19/2016 | 13:16:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|---|----|--------|--------|------|-------|-----------|--|----------------|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 025F | Home Economics Cold | EC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-050 | | Carter, Dan | 11/19/2016 | 13:16:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 025P | Home Economics Cold | EC | Copper | 0.227 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-049 | | Carter, Dan | 11/19/2016 | 13:14:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 025P | Home Economics Cold | EC | Lead | 0.0013 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-049 | | Carter, Dan | 11/19/2016 | 13:14:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 026F | Water Cooler 2nd Floor Across from 214 | WC | Copper | 0.186 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-052 | | Carter, Dan | 11/19/2016 | 13:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 026F | Water Cooler 2nd Floor Across from 214 | WC | Lead | 0.0022 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-052 | | Carter, Dan | 11/19/2016 | 13:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 026P | Water Cooler 2nd Floor Across from 214 | WC | Copper | 0.130 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-051 | | Carter, Dan | 11/19/2016 | 13:29:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 026P | Water Cooler 2nd Floor Across from 214 | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-051 | | Carter, Dan | 11/19/2016 | 13:29:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 027F | Water Cooler 2nd Floor Across from 214 | WC | Copper | 0.177 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-054 | | Carter, Dan | 11/19/2016 | 13:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 027F | Water Cooler 2nd Floor Across from 214 | WC | Lead | 0.0020 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-054 | | Carter, Dan | 11/19/2016 | 13:31:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 027P | Water Cooler 2nd Floor Across from 214 | WC | Copper | 0.175 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-053 | | Carter, Dan | 11/19/2016 | 13:27:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 027P | Water Cooler 2nd Floor Across from 214 | WC | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-053 | | Carter, Dan | 11/19/2016 | 13:27:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 028F | Classroom Faucet Room 213A | CF | Copper | 0.0845 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-056 | | Carter, Dan | 11/19/2016 | 13:38:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 028F | Classroom Faucet Room 213A | CF | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-056 | | Carter, Dan | 11/19/2016 | 13:38:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 028P | Classroom Faucet Room 213A | CF | Copper | 0.189 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-055 | | Carter, Dan | 11/19/2016 | 13:36:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 028P | Classroom Faucet Room 213A | CF | Lead | 0.0012 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-055 | | Carter, Dan | 11/19/2016 | 13:36:00 | 09-Dec-16 |

Tewksbury- John W. Wynn Middle 11-19-2016

| | | | | | | | | | | | | | | | | | | | |
|------|-----------|----------|---|------------------|------|---|----|--------|--------|------|-------|-----------|--|----------------|--|-------------|------------|----------|-----------|
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 029F | Classroom Faucet Room 213 | CF | Copper | 0.0862 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-058 | | Carter, Dan | 11/19/2016 | 13:38:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 029F | Classroom Faucet Room 213 | CF | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-058 | | Carter, Dan | 11/19/2016 | 13:38:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 029P | Classroom Faucet Room 213 | CF | Copper | 0.185 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-057 | | Carter, Dan | 11/19/2016 | 13:36:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 029P | Classroom Faucet Room 213 | CF | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-057 | | Carter, Dan | 11/19/2016 | 13:36:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 030F | Drinking Water Bubbler Outside Room 201 | DW | Copper | 0.405 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-060 | | Carter, Dan | 11/19/2016 | 13:44:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 030F | Drinking Water Bubbler Outside Room 201 | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-060 | | Carter, Dan | 11/19/2016 | 13:44:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 030P | Drinking Water Bubbler Outside Room 201 | DW | Copper | 0.889 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-059 | | Carter, Dan | 11/19/2016 | 13:43:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 030P | Drinking Water Bubbler Outside Room 201 | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-059 | | Carter, Dan | 11/19/2016 | 13:43:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 031F | Drinking Water Bubbler Outside Room 201 | DW | Copper | 0.431 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-062 | | Carter, Dan | 11/19/2016 | 13:44:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 031F | Drinking Water Bubbler Outside Room 201 | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-062 | | Carter, Dan | 11/19/2016 | 13:44:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 031P | Drinking Water Bubbler Outside Room 201 | DW | Copper | 1.42 | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-061 | | Carter, Dan | 11/19/2016 | 13:43:00 | 09-Dec-16 |
| LCCA | Tewksbury | 02950305 | Tewksbury: John W. Wynn Middle | Public School | 031P | Drinking Water Bubbler Outside Room 201 | DW | Lead | ND | mg/L | 0.001 | EPA 200.8 | GRANITE STATE ANALYTICAL SERVICES LLC | 1611-02416-061 | | Carter, Dan | 11/19/2016 | 13:43:00 | 09-Dec-16 |