

## Tewksbury- L F Dewing School 1-7-17

**The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.**

REPORT TYPE CODE	CITY TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOC ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Tewksbury	02950001	L F Dewing	Public School	001F	Kitchen Kettle Hot	KK	Lead	0.0020	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-002	Carter, Dan	1/7/2017	07:36:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	001F	Kitchen Kettle Hot	KK	Copper	0.0925	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-002	Carter, Dan	1/7/2017	07:36:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	001P	Kitchen Kettle Hot	KK	Lead	0.0060	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-001	Carter, Dan	1/7/2017	07:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	001P	Kitchen Kettle Hot	KK	Copper	0.0661	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-001	Carter, Dan	1/7/2017	07:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	002F	Kitchen Kettle Cold	KK	Lead	0.0040	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-004	Carter, Dan	1/7/2017	07:39:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	002F	Kitchen Kettle Cold	KK	Copper	0.205	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-004	Carter, Dan	1/7/2017	07:39:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	002P	Kitchen Kettle Cold	KK	Lead	0.0040	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-003	Carter, Dan	1/7/2017	07:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	002P	Kitchen Kettle Cold	KK	Copper	0.370	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-003	Carter, Dan	1/7/2017	07:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	003F	Kitchen Faucet Hot	KC	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-006	Carter, Dan	1/7/2017	07:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	003F	Kitchen Faucet Hot	KC	Copper	0.0815	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-006	Carter, Dan	1/7/2017	07:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	003P	Kitchen Faucet Hot	KC	Lead	0.0050	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-005	Carter, Dan	1/7/2017	07:42:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	003P	Kitchen Faucet Hot	KC	Copper	0.171	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-005	Carter, Dan	1/7/2017	07:42:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	004F	Kitchen Faucet Cold	KC	Lead	0.0034	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-008	Carter, Dan	1/7/2017	07:46:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	004F	Kitchen Faucet Cold	KC	Copper	0.0753	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-008	Carter, Dan	1/7/2017	07:46:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	004P	Kitchen Faucet Cold	KC	Lead	0.0042	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-007	Carter, Dan	1/7/2017	07:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	004P	Kitchen Faucet Cold	KC	Copper	0.112	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-007	Carter, Dan	1/7/2017	07:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	005F	Kitchen Faucet Hot	KC	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-010	Carter, Dan	1/7/2017	07:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	005F	Kitchen Faucet Hot	KC	Copper	0.112	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-010	Carter, Dan	1/7/2017	07:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	005P	Kitchen Faucet Hot	KC	Lead	0.0033	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-009	Carter, Dan	1/7/2017	09:54:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	005P	Kitchen Faucet Hot	KC	Copper	0.115	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-009	Carter, Dan	1/7/2017	09:54:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	006F	Kitchen Faucet Cold	KC	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-012	Carter, Dan	1/7/2017	07:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	006F	Kitchen Faucet Cold	KC	Copper	0.0379	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-012	Carter, Dan	1/7/2017	07:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	006P	Kitchen Faucet Cold	KC	Lead	0.0149	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-011	Carter, Dan	1/7/2017	07:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	006P	Kitchen Faucet Cold	KC	Copper	0.115	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-011	Carter, Dan	1/7/2017	07:56:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	007F	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-014	Carter, Dan	1/7/2017	07:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	007F	Kitchen Faucet Hot	KC	Copper	0.0596	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-014	Carter, Dan	1/7/2017	07:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	007P	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-013	Carter, Dan	1/7/2017	07:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	007P	Kitchen Faucet Hot	KC	Copper	0.0657	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-013	Carter, Dan	1/7/2017	07:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	008F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-016	Carter, Dan	1/7/2017	08:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	008F	Kitchen Faucet Cold	KC	Copper	0.0228	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-016	Carter, Dan	1/7/2017	08:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	008P	Kitchen Faucet Cold	KC	Lead	0.0044	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-015	Carter, Dan	1/7/2017	07:59:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	008P	Kitchen Faucet Cold	KC	Copper	0.0564	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-015	Carter, Dan	1/7/2017	07:59:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	009F	Drinking Water Bubblers Outside Staff Bathroom	DW	Lead	0.0084	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-018	Carter, Dan	1/7/2017	08:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	009F	Drinking Water Bubblers Outside Staff Bathroom	DW	Copper	0.0745	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-018	Carter, Dan	1/7/2017	08:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	009P	Drinking Water Bubblers Outside Staff Bathroom	DW	Lead	0.0054	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-017	Carter, Dan	1/7/2017	08:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	009P	Drinking Water Bubblers Outside Staff Bathroom	DW	Copper	0.205	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-017	Carter, Dan	1/7/2017	08:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	011F	Classroom Faucet B12	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-020	Carter, Dan	1/7/2017	08:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	011F	Classroom Faucet B12	CF	Copper	0.0617	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-020	Carter, Dan	1/7/2017	08:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	011P	Classroom Faucet B12	CF	Lead	0.0692	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-019	Carter, Dan	1/7/2017	08:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	011P	Classroom Faucet B12	CF	Copper	0.612	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-019	Carter, Dan	1/7/2017	08:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	012F	Classroom Faucet B11	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-022	Carter, Dan	1/7/2017	08:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	012F	Classroom Faucet B11	CF	Copper	0.0796	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-022	Carter, Dan	1/7/2017	08:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	012P	Classroom Faucet B11	CF	Lead	0.0033	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-021	Carter, Dan	1/7/2017	08:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	012P	Classroom Faucet B11	CF	Copper	0.121	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-021	Carter, Dan	1/7/2017	08:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	013F	Drinking Water Bubblers Room B11	DW	Lead	0.0035	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-024	Carter, Dan	1/7/2017	08:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	013F	Drinking Water Bubblers Room B11	DW	Copper	0.110	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-024	Carter, Dan	1/7/2017	08:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	013P	Drinking Water Bubblers Room B11	DW	Lead	0.0128	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-023	Carter, Dan	1/7/2017	08:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	013P	Drinking Water Bubblers Room B11	DW	Copper	0.161	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-023	Carter, Dan	1/7/2017	08:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	014F	Drinking Water Bubblers Room B10	DW	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-026	Carter, Dan	1/7/2017	08:25:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	014F	Drinking Water Bubblers Room B10	DW	Copper	0.0592	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-026	Carter, Dan	1/7/2017	08:25:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	014P	Drinking Water Bubblers Room B10	DW	Lead	0.0068	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-025	Carter, Dan	1/7/2017	08:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	014P	Drinking Water Bubblers Room B10	DW	Copper	0.102	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-025	Carter, Dan	1/7/2017	08:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	015F	Classroom Faucet B10	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-028	Carter, Dan	1/7/2017	08:28:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	015F	Classroom Faucet B10	CF	Copper	0.0427	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-028	Carter, Dan	1/7/2017	08:28:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	015P	Classroom Faucet B10	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-027	Carter, Dan	1/7/2017	08:27:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	015P	Classroom Faucet B10	CF	Copper	0.117	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-027	Carter, Dan	1/7/2017	08:27:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	016F	Drinking Water Bubblers Room B9	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-030	Carter, Dan	1/7/2017	08:31:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	016F	Drinking Water Bubblers Room B9	DW	Copper	0.148	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-030	Carter, Dan	1/7/2017	08:31:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	016P	Drinking Water Bubblers Room B9	DW	Lead	0.0021	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-029	Carter, Dan	1/7/2017	08:30:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	016P	Drinking Water Bubblers Room B9	DW	Copper	0.146	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-029	Carter, Dan	1/7/2017	08:30:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	017F	Classroom Faucet B9	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-032	Carter, Dan	1/7/2017	08:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	017F	Classroom Faucet B9	CF	Copper	0.102	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-032	Carter, Dan	1/7/2017	08:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	017P	Classroom Faucet B9	CF	Lead	0.0023	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-031	Carter, Dan	1/7/2017	08:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	017P	Classroom Faucet B9	CF	Copper	0.177	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-031	Carter, Dan	1/7/2017	08:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	019F	Classroom Faucet B8	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-034	Carter, Dan	1/7/2017	08:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	019F	Classroom Faucet B8	CF	Copper	0.0560	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-034	Carter, Dan	1/7/2017	08:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	019P	Classroom Faucet B8	CF	Lead	0.0024	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-033	Carter, Dan	1/7/2017	08:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	019P	Classroom Faucet B8	CF	Copper	0.238	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-033	Carter, Dan	1/7/2017	08:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	020F	Drinking Water Bubblers Room B7	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-036	Carter, Dan	1/7/2017	08:50:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	020F	Drinking Water Bubblers Room B7	DW	Copper	0.249	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-036	Carter, Dan	1/7/2017	08:50:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	020P	Drinking Water Bubblers Room B7	DW	Lead	0.0054	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-035	Carter, Dan	1/7/2017	08:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	020P	Drinking Water Bubblers Room B7	DW	Copper	0.322	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-035	Carter, Dan	1/7/2017	08:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	021F	Classroom Faucet B7	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-038	Carter, Dan	1/7/2017	08:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	021F	Classroom Faucet B7	CF	Copper	0.263	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-038	Carter, Dan	1/7/2017	08:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	021P	Classroom Faucet B7	CF	Lead	0.0036	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-037	Carter, Dan	1/7/2017	08:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	021P	Classroom Faucet B7	CF	Copper	0.280	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-037	Carter, Dan	1/7/2017	08:51:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	022F	Classroom Faucet B6	CF	Lead	0.0031	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-040	Carter, Dan	1/7/2017	08:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	022F	Classroom Faucet B6	CF	Copper	0.376	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-040	Carter, Dan	1/7/2017	08:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	022P	Classroom Faucet B6	CF	Lead	0.0039	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-039	Carter, Dan	1/7/2017	08:54:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	022P	Classroom Faucet B6	CF	Copper	0.328	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-039	Carter, Dan	1/7/2017	08:54:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	023F	Drinking Water bubbler Room B6	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-042	Carter, Dan	1/7/2017	08:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	023F	Drinking Water bubbler Room B6	DW	Copper	0.121	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-042	Carter, Dan	1/7/2017	08:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	023P	Drinking Water bubbler Room B6	DW	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-041	Carter, Dan	1/7/2017	08:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	023P	Drinking Water bubbler Room B6	DW	Copper	0.244	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-041	Carter, Dan	1/7/2017	08:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	024F	Drinking Water bubbler Room B5	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-044	Carter, Dan	1/7/2017	09:01:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	024F	Drinking Water bubbler Room B5	DW	Copper	0.0460	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-044	Carter, Dan	1/7/2017	09:01:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	024P	Drinking Water bubbler Room B5	DW	Lead	0.0058	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-043	Carter, Dan	1/7/2017	09:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	024P	Drinking Water bubbler Room B5	DW	Copper	0.234	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-043	Carter, Dan	1/7/2017	09:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	025F	Classroom Faucet B5	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-046	Carter, Dan	1/7/2017	09:02:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	025F	Classroom Faucet B5	CF	Copper	0.0450	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-046	Carter, Dan	1/7/2017	09:02:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	025P	Classroom Faucet B5	CF	Lead	0.0072	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-045	Carter, Dan	1/7/2017	09:01:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	025P	Classroom Faucet B5	CF	Copper	0.195	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-045	Carter, Dan	1/7/2017	09:01:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	026F	Drinking Water bubbler Room B4	DW	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-048	Carter, Dan	1/7/2017	09:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	026F	Drinking Water bubbler Room B4	DW	Copper	0.0411	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-048	Carter, Dan	1/7/2017	09:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	026P	Drinking Water bubbler Room B4	DW	Lead	0.0179	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-047	Carter, Dan	1/7/2017	09:03:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	026P	Drinking Water bubbler Room B4	DW	Copper	0.209	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-047	Carter, Dan	1/7/2017	09:03:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	027F	Classroom Faucet B4	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-050	Carter, Dan	1/7/2017	09:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	027F	Classroom Faucet B4	CF	Copper	0.0380	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-050	Carter, Dan	1/7/2017	09:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	027P	Classroom Faucet B4	CF	Lead	0.0074	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-049	Carter, Dan	1/7/2017	09:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	027P	Classroom Faucet B4	CF	Copper	0.143	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-049	Carter, Dan	1/7/2017	09:06:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	028F	Drinking Water bubbler Room B3	DW	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-052	Carter, Dan	1/7/2017	09:09:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	028F	Drinking Water bubbler Room B3	DW	Copper	0.0949	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-052	Carter, Dan	1/7/2017	09:09:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	028P	Drinking Water Bubblers Room B3	DW	Lead	0.0283	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-051	Carter, Dan	1/7/2017	09:08:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	028P	Drinking Water Bubblers Room B3	DW	Copper	0.465	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-051	Carter, Dan	1/7/2017	09:08:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	029F	Classroom Faucet B3	CF	Lead	0.0027	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-054	Carter, Dan	1/7/2017	09:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	029F	Classroom Faucet B3	CF	Copper	0.0468	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-054	Carter, Dan	1/7/2017	09:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	029P	Classroom Faucet B3	CF	Lead	0.0280	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-053	Carter, Dan	1/7/2017	09:09:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	029P	Classroom Faucet B3	CF	Copper	0.283	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-053	Carter, Dan	1/7/2017	09:09:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	030F	Drinking Water Bubblers Room B2	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-056	Carter, Dan	1/7/2017	09:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	030F	Drinking Water Bubblers Room B2	DW	Copper	0.0449	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-056	Carter, Dan	1/7/2017	09:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	030P	Drinking Water Bubblers Room B2	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-055	Carter, Dan	1/7/2017	09:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	030P	Drinking Water Bubblers Room B2	DW	Copper	0.112	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-055	Carter, Dan	1/7/2017	09:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	031F	Classroom Faucet B2	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-058	Carter, Dan	1/7/2017	09:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	031F	Classroom Faucet B2	CF	Copper	0.0366	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-058	Carter, Dan	1/7/2017	09:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	031P	Classroom Faucet B2	CF	Lead	0.0069	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-057	Carter, Dan	1/7/2017	09:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	031P	Classroom Faucet B2	CF	Copper	0.172	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-057	Carter, Dan	1/7/2017	09:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	032F	Classroom Faucet B1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-060	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	032F	Classroom Faucet B1	CF	Copper	0.0907	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-060	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	032P	Classroom Faucet B1	CF	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-059	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	032P	Classroom Faucet B1	CF	Copper	0.226	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-059	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	033F	Drinking Water Bubblers Room B1	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-062	Carter, Dan	1/7/2017	09:22:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	033F	Drinking Water Bubblers Room B1	DW	Copper	0.0930	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-062	Carter, Dan	1/7/2017	09:22:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	033P	Drinking Water Bubblers Room B1	DW	Lead	0.0245	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-061	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	033P	Drinking Water Bubblers Room B1	DW	Copper	0.462	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-061	Carter, Dan	1/7/2017	09:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	034F	Drinking Water Bubblers Room B13	DW	Lead	0.0269	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-064	Carter, Dan	1/7/2017	09:30:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	034F	Drinking Water Bubblers Room B13	DW	Copper	0.0896	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-064	Carter, Dan	1/7/2017	09:30:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	034P	Drinking Water Bubblers Room B13	DW	Lead	0.108	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-063	Carter, Dan	1/7/2017	09:28:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	034P	Drinking Water Bubblers Room B13	DW	Copper	0.422	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-063	Carter, Dan	1/7/2017	09:28:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	035F	Classroom Faucet B13	CF	Lead	0.0023	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-066	Carter, Dan	1/7/2017	09:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	035F	Classroom Faucet B13	CF	Copper	0.0261	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-066	Carter, Dan	1/7/2017	09:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	035P	Classroom Faucet B13	CF	Lead	0.0513	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-065	Carter, Dan	1/7/2017	09:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	035P	Classroom Faucet B13	CF	Copper	0.484	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-065	Carter, Dan	1/7/2017	09:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	036F	Classroom Faucet C8	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-068	Carter, Dan	1/7/2017	10:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	036F	Classroom Faucet C8	CF	Copper	0.0064	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-068	Carter, Dan	1/7/2017	10:32:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	036P	Classroom Faucet C8	CF	Lead	0.0026	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-067	Carter, Dan	1/7/2017	10:31:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	036P	Classroom Faucet C8	CF	Copper	0.0699	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-067	Carter, Dan	1/7/2017	10:31:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	037F	Classroom Faucet C8	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-070	Carter, Dan	1/7/2017	10:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	037F	Classroom Faucet C8	CF	Copper	0.0082	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-070	Carter, Dan	1/7/2017	10:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	037P	Classroom Faucet C8	CF	Lead	0.0035	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-069	Carter, Dan	1/7/2017	10:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	037P	Classroom Faucet C8	CF	Copper	0.0546	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-069	Carter, Dan	1/7/2017	10:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	040F	Classroom Faucet C22	CF	Lead	0.0094	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-072	Carter, Dan	1/7/2017	10:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	040F	Classroom Faucet C22	CF	Copper	0.197	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-072	Carter, Dan	1/7/2017	10:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	040P	Classroom Faucet C22	CF	Lead	0.133	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-071	Carter, Dan	1/7/2017	10:46:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	040P	Classroom Faucet C22	CF	Copper	0.969	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-071	Carter, Dan	1/7/2017	10:46:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	042F	Nurses Sink Hot	NS	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-074	Carter, Dan	1/7/2017	10:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	042F	Nurses Sink Hot	NS	Copper	0.0922	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-074	Carter, Dan	1/7/2017	10:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	042P	Nurses Sink Hot	NS	Lead	0.0039	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-073	Carter, Dan	1/7/2017	10:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	042P	Nurses Sink Hot	NS	Copper	0.234	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-073	Carter, Dan	1/7/2017	10:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	043F	Nurses Sink Cold	NS	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-076	Carter, Dan	1/7/2017	10:53:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	043F	Nurses Sink Cold	NS	Copper	0.0886	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-076	Carter, Dan	1/7/2017	10:53:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	043P	Nurses Sink Cold	NS	Lead	0.0098	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-075	Carter, Dan	1/7/2017	10:53:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	043P	Nurses Sink Cold	NS	Copper	0.174	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-075	Carter, Dan	1/7/2017	10:53:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	045F	Classroom Faucet C5	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-078	Carter, Dan	1/7/2017	11:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	045F	Classroom Faucet C5	CF	Copper	0.0416	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-078	Carter, Dan	1/7/2017	11:00:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	045P	Classroom Faucet C5	CF	Lead	0.0330	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-077	Carter, Dan	1/7/2017	10:59:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	045P	Classroom Faucet C5	CF	Copper	0.491	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-077	Carter, Dan	1/7/2017	10:59:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	047F	Classroom Faucet A13	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-080	Carter, Dan	1/7/2017	11:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	047F	Classroom Faucet A13	CF	Copper	0.0474	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-080	Carter, Dan	1/7/2017	11:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	047P	Classroom Faucet A13	CF	Lead	0.0690	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-079	Carter, Dan	1/7/2017	11:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	047P	Classroom Faucet A13	CF	Copper	0.652	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-079	Carter, Dan	1/7/2017	11:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	049F	Classroom Faucet A12	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-082	Carter, Dan	1/7/2017	11:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	049F	Classroom Faucet A12	CF	Copper	0.145	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-082	Carter, Dan	1/7/2017	11:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	049P	Classroom Faucet A12	CF	Lead	0.0022	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-081	Carter, Dan	1/7/2017	11:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	049P	Classroom Faucet A12	CF	Copper	0.166	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-081	Carter, Dan	1/7/2017	11:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	050F	Drinking Water Bubbler Room A11	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-084	Carter, Dan	1/7/2017	11:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	050F	Drinking Water Bubbler Room A11	DW	Copper	0.172	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-084	Carter, Dan	1/7/2017	11:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	050P	Drinking Water Bubbler Room A11	DW	Lead	0.0056	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-083	Carter, Dan	1/7/2017	11:12:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	050P	Drinking Water Bubbler Room A11	DW	Copper	0.323	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-083	Carter, Dan	1/7/2017	11:12:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	051F	Classroom Faucet A11	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-086	Carter, Dan	1/7/2017	11:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	051F	Classroom Faucet A11	CF	Copper	0.0958	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-086	Carter, Dan	1/7/2017	11:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	051P	Classroom Faucet A11	CF	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-085	Carter, Dan	1/7/2017	11:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	051P	Classroom Faucet A11	CF	Copper	0.167	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-085	Carter, Dan	1/7/2017	11:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	052F	Drinking Water Bubbler Room A10	DW	Lead	0.0024	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-088	Carter, Dan	1/7/2017	11:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	052F	Drinking Water Bubbler Room A10	DW	Copper	0.260	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-088	Carter, Dan	1/7/2017	11:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	052P	Drinking Water Bubbler Room A10	DW	Lead	0.0062	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-087	Carter, Dan	1/7/2017	11:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	052P	Drinking Water Bubbler Room A10	DW	Copper	0.562	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-087	Carter, Dan	1/7/2017	11:16:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	053F	Classroom Faucet A10	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-090	Carter, Dan	1/7/2017	11:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	053F	Classroom Faucet A10	CF	Copper	0.0807	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-090	Carter, Dan	1/7/2017	11:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	053P	Classroom Faucet A10	CF	Lead	0.0022	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-089	Carter, Dan	1/7/2017	11:17:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	053P	Classroom Faucet A10	CF	Copper	0.188	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-089	Carter, Dan	1/7/2017	11:17:00	02-Feb-17



## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	055F	Classroom Faucet A9	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-092	Carter, Dan	1/7/2017	11:24:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	055F	Classroom Faucet A9	CF	Copper	0.0960	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-092	Carter, Dan	1/7/2017	11:24:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	055P	Classroom Faucet A9	CF	Lead	0.0018	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-091	Carter, Dan	1/7/2017	11:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	055P	Classroom Faucet A9	CF	Copper	0.259	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-091	Carter, Dan	1/7/2017	11:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	056F	Drinking Water Bubblers Room A8	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-094	Carter, Dan	1/7/2017	11:34:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	056F	Drinking Water Bubblers Room A8	DW	Copper	0.0950	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-094	Carter, Dan	1/7/2017	11:34:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	056P	Drinking Water Bubblers Room A8	DW	Lead	0.0270	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-093	Carter, Dan	1/7/2017	11:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	056P	Drinking Water Bubblers Room A8	DW	Copper	0.651	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-093	Carter, Dan	1/7/2017	11:33:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	057F	Classroom Faucet A8	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-096	Carter, Dan	1/7/2017	11:36:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	057F	Classroom Faucet A8	CF	Copper	0.0931	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-096	Carter, Dan	1/7/2017	11:36:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	057P	Classroom Faucet A8	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-095	Carter, Dan	1/7/2017	11:35:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	057P	Classroom Faucet A8	CF	Copper	0.111	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-095	Carter, Dan	1/7/2017	11:35:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	058F	Classroom Faucet A7	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-098	Carter, Dan	1/7/2017	11:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	058F	Classroom Faucet A7	CF	Copper	0.565	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-098	Carter, Dan	1/7/2017	11:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	058P	Classroom Faucet A7	CF	Lead	0.0029	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-097	Carter, Dan	1/7/2017	11:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	058P	Classroom Faucet A7	CF	Copper	0.367	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-097	Carter, Dan	1/7/2017	11:38:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	059F	Drinking Water Bubblers Room A7	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-100	Carter, Dan	1/7/2017	11:40:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	059F	Drinking Water Bubblers Room A7	DW	Copper	0.440	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-100	Carter, Dan	1/7/2017	11:40:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	059P	Drinking Water Bubblers Room A7	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-099	Carter, Dan	1/7/2017	11:39:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	059P	Drinking Water Bubblers Room A7	DW	Copper	0.477	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-099	Carter, Dan	1/7/2017	11:39:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	060F	Drinking Water Bubblers Room A6	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-102	Carter, Dan	1/7/2017	11:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	060F	Drinking Water Bubblers Room A6	DW	Copper	0.420	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-102	Carter, Dan	1/7/2017	11:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	060P	Drinking Water Bubblers Room A6	DW	Lead	0.0038	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-101	Carter, Dan	1/7/2017	11:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	060P	Drinking Water Bubblers Room A6	DW	Copper	0.387	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-101	Carter, Dan	1/7/2017	11:43:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	061F	Classroom Faucet A6	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-104	Carter, Dan	1/7/2017	11:45:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	061F	Classroom Faucet A6	CF	Copper	0.353	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-104	Carter, Dan	1/7/2017	11:45:00	02-Feb-17



## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	061P	Classroom Faucet A6	CF	Lead	0.0036	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-103	Carter, Dan	1/7/2017	11:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	061P	Classroom Faucet A6	CF	Copper	0.247	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-103	Carter, Dan	1/7/2017	11:44:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	062F	Drinking Water bubbler Room A5	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-106	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	062F	Drinking Water bubbler Room A5	DW	Copper	0.274	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-106	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	062P	Drinking Water bubbler Room A5	DW	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-105	Carter, Dan	1/7/2017	11:47:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	062P	Drinking Water bubbler Room A5	DW	Copper	0.402	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-105	Carter, Dan	1/7/2017	11:47:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	063F	Classroom Faucet A5	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-108	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	063F	Classroom Faucet A5	CF	Copper	0.168	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-108	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	063P	Classroom Faucet A5	CF	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-107	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	063P	Classroom Faucet A5	CF	Copper	0.356	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-107	Carter, Dan	1/7/2017	11:48:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	064F	Drinking Water bubbler Room A4	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-110	Carter, Dan	1/7/2017	11:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	064F	Drinking Water bubbler Room A4	DW	Copper	0.170	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-110	Carter, Dan	1/7/2017	11:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	064P	Drinking Water bubbler Room A4	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-109	Carter, Dan	1/7/2017	11:50:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	064P	Drinking Water bubbler Room A4	DW	Copper	0.274	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-109	Carter, Dan	1/7/2017	11:50:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	065F	Classroom Faucet A4	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-112	Carter, Dan	1/7/2017	11:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	065F	Classroom Faucet A4	CF	Copper	0.124	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-112	Carter, Dan	1/7/2017	11:52:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	065P	Classroom Faucet A4	CF	Lead	0.0014	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-111	Carter, Dan	1/7/2017	11:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	065P	Classroom Faucet A4	CF	Copper	0.294	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-111	Carter, Dan	1/7/2017	11:51:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	066F	Drinking Water bubbler Room A3	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-114	Carter, Dan	1/7/2017	11:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	066F	Drinking Water bubbler Room A3	DW	Copper	0.133	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-114	Carter, Dan	1/7/2017	11:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	066P	Drinking Water bubbler Room A3	DW	Lead	0.0027	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-113	Carter, Dan	1/7/2017	11:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	066P	Drinking Water bubbler Room A3	DW	Copper	0.337	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-113	Carter, Dan	1/7/2017	11:55:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	067F	Classroom Faucet A3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-116	Carter, Dan	1/7/2017	11:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	067F	Classroom Faucet A3	CF	Copper	0.0730	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-116	Carter, Dan	1/7/2017	11:57:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	067P	Classroom Faucet A3	CF	Lead	0.0022	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-115	Carter, Dan	1/7/2017	11:56:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	067P	Classroom Faucet A3	CF	Copper	0.240	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-115	Carter, Dan	1/7/2017	11:56:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	068F	Classroom Faucet A2	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-118	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	068F	Classroom Faucet A2	CF	Copper	0.0703	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-118	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	068P	Classroom Faucet A2	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-117	Carter, Dan	1/7/2017	11:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	068P	Classroom Faucet A2	CF	Copper	0.340	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-117	Carter, Dan	1/7/2017	11:58:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	069F	Drinking Water bubbler Room A2	DW	Lead	0.0010	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-120	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	069F	Drinking Water bubbler Room A2	DW	Copper	0.0671	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-120	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	069P	Drinking Water bubbler Room A2	DW	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-119	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	069P	Drinking Water bubbler Room A2	DW	Copper	0.159	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-119	Carter, Dan	1/7/2017	12:00:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	070F	Classroom Faucet A1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-122	Carter, Dan	1/7/2017	12:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	070F	Classroom Faucet A1	CF	Copper	0.0469	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-122	Carter, Dan	1/7/2017	12:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	070P	Classroom Faucet A1	CF	Lead	0.0046	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-121	Carter, Dan	1/7/2017	12:02:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	070P	Classroom Faucet A1	CF	Copper	0.244	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-121	Carter, Dan	1/7/2017	12:02:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	071F	Drinking Water bubbler Room A1	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-124	Carter, Dan	1/7/2017	12:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	071F	Drinking Water bubbler Room A1	DW	Copper	0.0564	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-124	Carter, Dan	1/7/2017	12:05:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	071P	Drinking Water bubbler Room A1	DW	Lead	0.0085	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-123	Carter, Dan	1/7/2017	12:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	071P	Drinking Water bubbler Room A1	DW	Copper	0.168	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-123	Carter, Dan	1/7/2017	12:04:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	072F	Drinking Water bubbler Room C1	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-126	Carter, Dan	1/7/2017	12:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	072F	Drinking Water bubbler Room C1	DW	Copper	0.0453	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-126	Carter, Dan	1/7/2017	12:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	072P	Drinking Water bubbler Room C1	DW	Lead	0.0075	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-125	Carter, Dan	1/7/2017	12:09:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	072P	Drinking Water bubbler Room C1	DW	Copper	0.250	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-125	Carter, Dan	1/7/2017	12:09:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	073F	Classroom Faucet C1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-128	Carter, Dan	1/7/2017	12:11:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	073F	Classroom Faucet C1	CF	Copper	0.0324	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-128	Carter, Dan	1/7/2017	12:11:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	073P	Classroom Faucet C1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-127	Carter, Dan	1/7/2017	12:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	073P	Classroom Faucet C1	CF	Copper	0.0665	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-127	Carter, Dan	1/7/2017	12:10:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	074F	Drinking Water bubbler Room C2	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-130	Carter, Dan	1/7/2017	12:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	074F	Drinking Water bubbler Room C2	DW	Copper	0.0628	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-130	Carter, Dan	1/7/2017	12:14:00	02-Feb-17

## Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	074P	Drinking Water Bubblers Room C2	DW	Lead	0.0163	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-129	Carter, Dan	1/7/2017	12:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	074P	Drinking Water Bubblers Room C2	DW	Copper	0.953	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-129	Carter, Dan	1/7/2017	12:13:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	075F	Classroom Faucet C2	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-132	Carter, Dan	1/7/2017	12:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	075F	Classroom Faucet C2	CF	Copper	0.0443	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-132	Carter, Dan	1/7/2017	12:15:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	075P	Classroom Faucet C2	CF	Lead	0.0011	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-131	Carter, Dan	1/7/2017	12:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	075P	Classroom Faucet C2	CF	Copper	0.101	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-131	Carter, Dan	1/7/2017	12:14:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	076F	Drinking Water Bubblers Room C3	DW	Lead	0.0016	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-134	Carter, Dan	1/7/2017	12:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	076F	Drinking Water Bubblers Room C3	DW	Copper	0.0604	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-134	Carter, Dan	1/7/2017	12:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	076P	Drinking Water Bubblers Room C3	DW	Lead	0.116	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-133	Carter, Dan	1/7/2017	12:17:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	076P	Drinking Water Bubblers Room C3	DW	Copper	1.02	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-133	Carter, Dan	1/7/2017	12:17:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	077F	Classroom Faucet C3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-136	Carter, Dan	1/7/2017	12:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	077F	Classroom Faucet C3	CF	Copper	0.0453	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-136	Carter, Dan	1/7/2017	12:19:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	077P	Classroom Faucet C3	CF	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-135	Carter, Dan	1/7/2017	12:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	077P	Classroom Faucet C3	CF	Copper	0.0869	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-135	Carter, Dan	1/7/2017	12:18:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	078F	Classroom Faucet C4	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-138	Carter, Dan	1/7/2017	12:22:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	078F	Classroom Faucet C4	CF	Copper	0.0646	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-138	Carter, Dan	1/7/2017	12:22:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	078P	Classroom Faucet C4	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-137	Carter, Dan	1/7/2017	12:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	078P	Classroom Faucet C4	CF	Copper	0.190	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-137	Carter, Dan	1/7/2017	12:21:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	079F	Drinking Water Bubblers Room C4	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-140	Carter, Dan	1/7/2017	12:24:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	079F	Drinking Water Bubblers Room C4	DW	Copper	0.0754	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-140	Carter, Dan	1/7/2017	12:24:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	079P	Drinking Water Bubblers Room C4	DW	Lead	0.0043	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-139	Carter, Dan	1/7/2017	12:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	079P	Drinking Water Bubblers Room C4	DW	Copper	0.274	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-139	Carter, Dan	1/7/2017	12:23:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	080F	Drinking Water Bubblers Gym	DW	Lead	0.0050	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-142	Carter, Dan	1/7/2017	12:27:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	080F	Drinking Water Bubblers Gym	DW	Copper	0.299	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-142	Carter, Dan	1/7/2017	12:27:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	080P	Drinking Water Bubblers Gym	DW	Lead	0.0129	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-141	Carter, Dan	1/7/2017	12:27:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	080P	Drinking Water Bubblers Gym	DW	Copper	0.320	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-141	Carter, Dan	1/7/2017	12:27:00	02-Feb-17

### Tewksbury- L F Dewing School 1-7-17

LCCA	Tewksbury	02950001	L F Dewing	Public School	081F	Drinking Water Bubbler Gym	DW	Lead	0.0043	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-144	Carter, Dan	1/7/2017	12:29:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	081F	Drinking Water Bubbler Gym	DW	Copper	0.613	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-144	Carter, Dan	1/7/2017	12:29:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	081P	Drinking Water Bubbler Gym	DW	Lead	0.0051	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-143	Carter, Dan	1/7/2017	12:28:00	02-Feb-17
LCCA	Tewksbury	02950001	L F Dewing	Public School	081P	Drinking Water Bubbler Gym	DW	Copper	0.504	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES	1701-01517-143	Carter, Dan	1/7/2017	12:28:00	02-Feb-17