Tewksbury- North Street 11-19-2016

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOC ID	SAMPLE LOCATION NAME	SAMPLE COMMENT	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	001F	Classroom Faucet Room 14	CF	Copper	0.0106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-002		Marchand, Jon	11/19/2016	08:10:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	001F	Classroom Faucet Room 14	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-002		Marchand, Jon	11/19/2016	08:10:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	001P	Classroom Faucet Room 14	CF	Copper	0.121	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-001		Marchand, Jon	11/19/2016	08:07:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	001P	Classroom Faucet Room 14	CF	Lead	0.0053	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-001		Marchand, Jon	11/19/2016	08:07:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	002F	Drinking Water Bubbler Room 14	DW	Copper	0.0344	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-004		Marchand, Jon	11/19/2016	08:11:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	002F	Drinking Water Bubbler Room 14	DW	Lead	0.0022	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-004		Marchand, Jon	11/19/2016	08:11:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	002P	Drinking Water Bubbler Room 14	DW	Copper	0.114	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-003		Marchand, Jon	11/19/2016	08:08:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	002P	Drinking Water Bubbler Room 14	DW	Lead	0.0088	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-003		Marchand, Jon	11/19/2016	08:08:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	004F	Classroom Faucet Room 13	CF	Copper	0.0123	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-006		Marchand, Jon	11/19/2016	08:17:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	004F	Classroom Faucet Room 13	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-006		Marchand, Jon	11/19/2016	08:17:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	004P	Classroom Faucet Room 13	CF	Copper	0.0718	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-005		Marchand, Jon	11/19/2016	08:16:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	004P	Classroom Faucet Room 13	CF	Lead	0.0093	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-005		Marchand, Jon	11/19/2016	08:16:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	005F	Classroom Faucet Room 12	CF	Copper	0.0201	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-008		Marchand, Jon	11/19/2016	08:27:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	005F	Classroom Faucet Room 12	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-008		Marchand, Jon	11/19/2016	08:27:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	005P	Classroom Faucet Room 12	CF	Copper	0.100	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-007		Marchand, Jon	11/19/2016	08:26:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	005P	Classroom Faucet Room 12	CF	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-007		Marchand, Jon	11/19/2016	08:26:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	007F	Classroom Faucet Room 11	CF	Copper	0.0241	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-010		Marchand, Jon	11/19/2016	08:32:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	007F	Classroom Faucet Room 11	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-010		Marchand, Jon	11/19/2016	08:32:00	09-Dec-16

Tewksbury- North Street 11-19-2016

LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	007P	Classroom Faucet Room 11	CF	Copper	0.0941	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-009		Marchand, Jon	11/19/2016	08:31:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	007P	Classroom Faucet Room 11	CF	Lead	0.0047	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-009		Marchand, Jon	11/19/2016	08:31:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	008F	Drinking Water Bubbler Room 11	DW	Copper	0.0206	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-012		Marchand, Jon	11/19/2016	08:35:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	008F	Drinking Water Bubbler Room 11	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-012		Marchand, Jon	11/19/2016	08:35:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	008P	Drinking Water Bubbler Room 11	DW	Copper	0.0898	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-011		Marchand, Jon	11/19/2016	08:33:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	008P	Drinking Water Bubbler Room 11	DW	Lead	0.0047	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-011		Marchand, Jon	11/19/2016	08:33:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	009F	Classroom Faucet Room 10	CF	Copper	0.113	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-014		Marchand, Jon	11/19/2016	08:39:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	009F	Classroom Faucet Room 10	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-014		Marchand, Jon	11/19/2016	08:39:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	009P	Classroom Faucet Room 10	CF	Copper	0.201	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-013		Marchand, Jon	11/19/2016	08:38:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	009P	Classroom Faucet Room 10	CF	Lead	0.0024	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-013		Marchand, Jon	11/19/2016	08:38:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	011F	Classroom Faucet Room 9	CF	Copper	0.0589	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-016		Marchand, Jon	11/19/2016	08:44:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	011F	Classroom Faucet Room 9	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-016		Marchand, Jon	11/19/2016	08:44:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	011P	Classroom Faucet Room 9	CF	Copper	0.203	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-015		Marchand, Jon	11/19/2016	08:43:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	011P	Classroom Faucet Room 9	CF	Lead	0.0029	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-015		Marchand, Jon	11/19/2016	08:43:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	012F	Drinking Water Bubbler Room 9	DW	Copper	0.0443	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-018		Marchand, Jon	11/19/2016	08:46:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	012F	Drinking Water Bubbler Room 9	DW	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-018		Marchand, Jon	11/19/2016	08:46:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	012P	Drinking Water Bubbler Room 9	DW	Copper	0.340	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-017		Marchand, Jon	11/19/2016	08:44:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	012P	Drinking Water Bubbler Room 9	DW	Lead	0.0105	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-017		Marchand, Jon	11/19/2016	08:44:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	014F	Drinking Water Bubbler Inside Gym	DW	Copper	0.256	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-020		Marchand, Jon	11/19/2016	08:52:00	09-Dec-16

Tewksbury- North Street 11-19-2016

LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	014F	Drinking Water Bubbler Inside Gym	DW	Lead	0.0020	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-020		Marchand, Jon	11/19/2016	08:52:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	014P	Drinking Water Bubbler Inside Gym	DW	Copper	0.255	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-019		Marchand, Jon	11/19/2016	08:51:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	014P	Drinking Water Bubbler Inside Gym	DW	Lead	0.0071	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-019		Marchand, Jon	11/19/2016	08:51:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	021F	Classroom Faucet Room 8	CF	Copper	0.110	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-022		Marchand, Jon	11/19/2016	09:07:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	021F	Classroom Faucet Room 8	CF	Lead	0.0023	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-022		Marchand, Jon	11/19/2016	09:07:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	021P	Classroom Faucet Room 8	CF	Copper	0.110	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-021		Marchand, Jon	11/19/2016	09:06:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	021P	Classroom Faucet Room 8	CF	Lead	0.0052	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-021		Marchand, Jon	11/19/2016	09:06:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	025F	Classroom Faucet Room 6	CF	Copper	0.0269	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-024		Marchand, Jon	11/19/2016	09:22:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	025F	Classroom Faucet Room 6	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-024		Marchand, Jon	11/19/2016	09:22:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	025P	Classroom Faucet Room 6	CF	Copper	0.184	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-023		Marchand, Jon	11/19/2016	09:21:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	025P	Classroom Faucet Room 6	CF	Lead	0.0048	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-023		Marchand, Jon	11/19/2016	09:21:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	027F	Classroom Faucet Room 5	CF	Copper	0.0220	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-026		Marchand, Jon	11/19/2016	09:29:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	027F	Classroom Faucet Room 5	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-026		Marchand, Jon	11/19/2016	09:29:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	027P	Classroom Faucet Room 5	CF	Copper	0.164	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-025		Marchand, Jon	11/19/2016	09:28:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	027P	Classroom Faucet Room 5	CF	Lead	0.0021	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-025		Marchand, Jon	11/19/2016	09:28:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	028F	Drinking Water Bubbler Room 5	DW	Copper	0.0223	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-028		Marchand, Jon	11/19/2016	09:30:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	028F	Drinking Water Bubbler Room 5	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-028		Marchand, Jon	11/19/2016	09:30:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	028P	Drinking Water Bubbler Room 5	DW	Copper	0.0201	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-027		Marchand, Jon	11/19/2016	09:28:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	028P	Drinking Water Bubbler Room 5	DW	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-027		Marchand, Jon	11/19/2016	09:28:00	09-Dec-16

Tewksbury- North Street 11-19-2016

LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	029F	Classroom Faucet Room 4	CF	Copper	0.0189	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-030		Marchand, Jon	11/19/2016	09:36:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	029F	Classroom Faucet Room 4	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-030		Marchand, Jon	11/19/2016	09:36:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	029P	Classroom Faucet Room 4	CF	Copper	0.104	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-029		Marchand, Jon	11/19/2016	09:34:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	029P	Classroom Faucet Room 4	CF	Lead	0.0117	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-029		Marchand, Jon	11/19/2016	09:34:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	032F	Classroom Faucet Room 3	CF	Copper	0.0068	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-032		Marchand, Jon	11/19/2016	09:41:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	032F	Classroom Faucet Room 3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-032		Marchand, Jon	11/19/2016	09:41:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	032P	Classroom Faucet Room 3	CF	Copper	0.0940	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-031		Marchand, Jon	11/19/2016	09:40:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	032P	Classroom Faucet Room 3	CF	Lead	0.0028	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-031		Marchand, Jon	11/19/2016	09:40:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	034F	Classroom Faucet Room 2	CF	Copper	0.206	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-034		Marchand, Jon	11/19/2016	09:51:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	034F	Classroom Faucet Room 2	CF	Lead	0.0099	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-034		Marchand, Jon	11/19/2016	09:51:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	034P	Classroom Faucet Room 2	CF	Copper	1.52	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-033		Marchand, Jon	11/19/2016	09:49:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	034P	Classroom Faucet Room 2	CF	Lead	0.160	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-033		Marchand, Jon	11/19/2016	09:49:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	036F	Drinking Water Bubbler Room 1	DW	Copper	0.0525	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-036		Marchand, Jon	11/19/2016	09:59:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	036F	Drinking Water Bubbler Room 1	DW	Lead	0.0376	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-036		Marchand, Jon	11/19/2016	09:59:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	036P	Drinking Water Bubbler Room 1	DW	Copper	0.144	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-035		Marchand, Jon	11/19/2016	09:58:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	036P	Drinking Water Bubbler Room 1	DW	Lead	0.0129	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-035		Marchand, Jon	11/19/2016	09:58:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	037F	Classroom Faucet Room 1	CF	Copper	0.0104	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-038		Marchand, Jon	11/19/2016	10:00:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	037F	Classroom Faucet Room 1	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-038		Marchand, Jon	11/19/2016	10:00:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	037P	Classroom Faucet Room 1	CF	Copper	0.107	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-037		Marchand, Jon	11/19/2016	09:59:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	037P	Classroom Faucet Room 1	CF	Lead	0.0051	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-037		Marchand, Jon	11/19/2016	09:59:00	09-Dec-16

Tewksbury- North Street 11-19-2016

LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	038F	Classroom Faucet Reading Room	CF	Copper	0.0159	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-040		Marchand, Jon	11/19/2016	10:04:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	038F	Classroom Faucet Reading Room	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-040		Marchand, Jon	11/19/2016	10:04:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	038P	Classroom Faucet Reading Room	CF	Copper	0.305	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-039		Marchand, Jon	11/19/2016	10:03:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	038P	Classroom Faucet Reading Room	CF	Lead	0.0181	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-039		Marchand, Jon	11/19/2016	10:03:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	039F	Kitchen Faucet Cold	KC	Copper	0.0062	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-042		Marchand, Jon	11/19/2016	10:11:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	039F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-042		Marchand, Jon	11/19/2016	10:11:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	039P	Kitchen Faucet Cold	KC	Copper	0.0665	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-041		Marchand, Jon	11/19/2016	10:10:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	039P	Kitchen Faucet Cold	KC	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-041		Marchand, Jon	11/19/2016	10:10:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	040F	Kitchen Faucet Hot	KC	Copper	0.0992	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-044		Marchand, Jon	11/19/2016	10:13:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	040F	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-044		Marchand, Jon	11/19/2016	10:13:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	040P	Kitchen Faucet Hot	KC	Copper	0.0300	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-043		Marchand, Jon	11/19/2016	10:12:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	040P	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-043		Marchand, Jon	11/19/2016	10:12:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	041F	Kitchen Faucet Cold	KC	Copper	0.0042	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-046		Marchand, Jon	11/19/2016	10:14:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	041F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-046		Marchand, Jon	11/19/2016	10:14:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	041P	Kitchen Faucet Cold	KC	Copper	0.0394	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-045		Marchand, Jon	11/19/2016	10:13:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	041P	Kitchen Faucet Cold	KC	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-045		Marchand, Jon	11/19/2016	10:13:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	042F	Kitchen Faucet Hot	KC	Copper	0.0721	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-048		Marchand, Jon	11/19/2016	10:15:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	042F	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-048		Marchand, Jon	11/19/2016	10:15:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	042P	Kitchen Faucet Hot	KC	Copper	0.0424	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-047		Marchand, Jon	11/19/2016	10:14:00	09-Dec-16
LCCA	Tewksbury	02950020	Tewksbury: North Street	Public School	042P	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1611-02409-047		Marchand, Jon	11/19/2016	10:14:00	09-Dec-16