

Tewksbury- Memorial High School 12-17-2016

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

REPORT TYPE CODE	CITY TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOC ID	SAMPLE LOCATION NAME	SAMPLE COMMENTS	ANALYTE NAME	RESULT	UNITS OF MEASUREMENT	METHOD DETECTION LIMIT	ANALYTICAL METHOD USED	ANALYSIS LAB	LAB SAMPLE ID	SAMPLER NAME	SAMPLE COLLECTION DATE	SAMPLE COLLECTION TIME	REPORT DATE
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	001F	Kitchen Kettle Cold	KK	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-002	Martin, Dan	12/17/2016	08:57:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	001F	Kitchen Kettle Cold	KK	Copper	0.249	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-002	Martin, Dan	12/17/2016	08:57:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	001P	Kitchen Kettle Cold	KK	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-001	Martin, Dan	12/17/2016	08:57:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	001P	Kitchen Kettle Cold	KK	Copper	0.257	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-001	Martin, Dan	12/17/2016	08:57:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	002F	Kitchen Kettle Hot	KK	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-004	Martin, Dan	12/17/2016	08:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	002F	Kitchen Kettle Hot	KK	Copper	0.235	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-004	Martin, Dan	12/17/2016	08:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	002P	Kitchen Kettle Hot	KK	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-003	Martin, Dan	12/17/2016	08:58:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	002P	Kitchen Kettle Hot	KK	Copper	0.562	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-003	Martin, Dan	12/17/2016	08:58:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	003F	Kitchen Ice Maker	KI	Lead	0.0029	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-006	Martin, Dan	12/17/2016	09:03:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	003F	Kitchen Ice Maker	KI	Copper	0.111	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-006	Martin, Dan	12/17/2016	09:03:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	003P	Kitchen Ice Maker	KI	Lead	0.0037	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-005	Martin, Dan	12/17/2016	09:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	003P	Kitchen Ice Maker	KI	Copper	0.134	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-005	Martin, Dan	12/17/2016	09:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	004F	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-008	Martin, Dan	12/17/2016	09:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	004F	Kitchen Faucet Cold	KC	Copper	0.0327	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-008	Martin, Dan	12/17/2016	09:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	004P	Kitchen Faucet Cold	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-007	Martin, Dan	12/17/2016	09:04:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	004P	Kitchen Faucet Cold	KC	Copper	0.287	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-007	Martin, Dan	12/17/2016	09:04:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	005F	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-010	Martin, Dan	12/17/2016	09:07:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	005F	Kitchen Faucet Hot	KC	Copper	0.220	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-010	Martin, Dan	12/17/2016	09:07:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	005P	Kitchen Faucet Hot	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-009	Martin, Dan	12/17/2016	09:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	005P	Kitchen Faucet Hot	KC	Copper	0.323	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-009	Martin, Dan	12/17/2016	09:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	006F	Kitchen Faucet Hot Room B103	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-012	Martin, Dan	12/17/2016	09:16:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	006F	Kitchen Faucet Hot Room B103	KC	Copper	0.246	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-012	Martin, Dan	12/17/2016	09:16:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	006P	Kitchen Faucet Hot Room B103	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-011	Martin, Dan	12/17/2016	09:16:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	006P	Kitchen Faucet Hot Room B103	KC	Copper	0.354	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-011	Martin, Dan	12/17/2016	09:16:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	007F	Kitchen Faucet Cold Room B103	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-014	Martin, Dan	12/17/2016	09:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	007F	Kitchen Faucet Cold Room B103	KC	Copper	0.185	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-014	Martin, Dan	12/17/2016	09:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	007P	Kitchen Faucet Cold Room B103	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-013	Martin, Dan	12/17/2016	09:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	007P	Kitchen Faucet Cold Room B103	KC	Copper	0.221	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-013	Martin, Dan	12/17/2016	09:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	008F	Water Cooler Outside Room LG1	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-016	Martin, Dan	12/17/2016	09:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	008F	Water Cooler Outside Room LG1	WC	Copper	0.677	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-016	Martin, Dan	12/17/2016	09:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	008P	Water Cooler Outside Room LG1	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-015	Martin, Dan	12/17/2016	09:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	008P	Water Cooler Outside Room LG1	WC	Copper	0.590	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-015	Martin, Dan	12/17/2016	09:21:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	009F	Water Cooler Outside Room LG1	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-018	Martin, Dan	12/17/2016	09:25:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	009F	Water Cooler Outside Room LG1	WC	Copper	0.436	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-018	Martin, Dan	12/17/2016	09:25:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	009P	Water Cooler Outside Room LG1	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-017	Martin, Dan	12/17/2016	09:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	009P	Water Cooler Outside Room LG1	WC	Copper	0.567	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-017	Martin, Dan	12/17/2016	09:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	010F	Kitchen Faucet Hot Room B111	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-020	Martin, Dan	12/17/2016	09:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	010F	Kitchen Faucet Hot Room B111	KC	Copper	0.194	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-020	Martin, Dan	12/17/2016	09:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	010P	Kitchen Faucet Hot Room B111	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-019	Martin, Dan	12/17/2016	09:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	010P	Kitchen Faucet Hot Room B111	KC	Copper	0.290	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-019	Martin, Dan	12/17/2016	09:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	011F	Kitchen Faucet Cold Room B111	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-022	Martin, Dan	12/17/2016	09:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	011F	Kitchen Faucet Cold Room B111	KC	Copper	0.248	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-022	Martin, Dan	12/17/2016	09:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	011P	Kitchen Faucet Cold Room B111	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-021	Martin, Dan	12/17/2016	09:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	011P	Kitchen Faucet Cold Room B111	KC	Copper	0.250	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-021	Martin, Dan	12/17/2016	09:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	012F	Kitchen Faucet Cold Room B111.2	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-024	Martin, Dan	12/17/2016	09:41:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	012F	Kitchen Faucet Cold Room B111.2	KC	Copper	0.136	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-024	Martin, Dan	12/17/2016	09:41:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	012P	Kitchen Faucet Cold Room B111.2	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-023	Martin, Dan	12/17/2016	09:41:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	012P	Kitchen Faucet Cold Room B111.2	KC	Copper	0.174	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-023	Martin, Dan	12/17/2016	09:41:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	013F	Kitchen Faucet Cold Room B111.2	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-026	Martin, Dan	12/17/2016	09:43:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	013F	Kitchen Faucet Cold Room B111.2	KC	Copper	0.238	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-026	Martin, Dan	12/17/2016	09:43:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	013P	Kitchen Faucet Cold Room B111.2	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-025	Martin, Dan	12/17/2016	09:43:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	013P	Kitchen Faucet Cold Room B111.2	KC	Copper	0.264	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-025	Martin, Dan	12/17/2016	09:43:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	015F	Water Cooler Outside TV Studio	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-028	Martin, Dan	12/17/2016	09:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	015F	Water Cooler Outside TV Studio	WC	Copper	0.106	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-028	Martin, Dan	12/17/2016	09:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	015P	Water Cooler Outside TV Studio	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-027	Martin, Dan	12/17/2016	09:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	015P	Water Cooler Outside TV Studio	WC	Copper	0.0923	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-027	Martin, Dan	12/17/2016	09:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	016F	Water Cooler Outside TV Studio	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-030	Martin, Dan	12/17/2016	10:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	016F	Water Cooler Outside TV Studio	WC	Copper	0.125	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-030	Martin, Dan	12/17/2016	10:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	016P	Water Cooler Outside TV Studio	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-029	Martin, Dan	12/17/2016	10:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	016P	Water Cooler Outside TV Studio	WC	Copper	0.115	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-029	Martin, Dan	12/17/2016	10:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	017F	Kitchen Faucet Hot Room A109	KC	Lead	0.0017	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-032	Martin, Dan	12/17/2016	10:06:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	017F	Kitchen Faucet Hot Room A109	KC	Copper	0.268	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-032	Martin, Dan	12/17/2016	10:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	017P	Kitchen Faucet Hot Room A109	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-031	Martin, Dan	12/17/2016	10:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	017P	Kitchen Faucet Hot Room A109	KC	Copper	0.301	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-031	Martin, Dan	12/17/2016	10:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	018F	Kitchen Faucet Cold Room A109	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-034	Martin, Dan	12/17/2016	10:08:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	018F	Kitchen Faucet Cold Room A109	KC	Copper	0.245	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-034	Martin, Dan	12/17/2016	10:08:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	018P	Kitchen Faucet Cold Room A109	KC	Lead	0.0018	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-033	Martin, Dan	12/17/2016	10:07:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	018P	Kitchen Faucet Cold Room A109	KC	Copper	0.230	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-033	Martin, Dan	12/17/2016	10:07:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	019F	Classroom Faucet Hot Room A110	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-036	Martin, Dan	12/17/2016	10:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	019F	Classroom Faucet Hot Room A110	CF	Copper	0.295	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-036	Martin, Dan	12/17/2016	10:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	019P	Classroom Faucet Hot Room A110	CF	Lead	0.0015	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-035	Martin, Dan	12/17/2016	10:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	019P	Classroom Faucet Hot Room A110	CF	Copper	0.297	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-035	Martin, Dan	12/17/2016	10:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	020F	Classroom Faucet Cold Room A110	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-038	Martin, Dan	12/17/2016	10:18:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	020F	Classroom Faucet Cold Room A110	CF	Copper	0.199	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-038	Martin, Dan	12/17/2016	10:18:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	020P	Classroom Faucet Cold Room A110	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-037	Martin, Dan	12/17/2016	10:18:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	020P	Classroom Faucet Cold Room A110	CF	Copper	0.421	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-037	Martin, Dan	12/17/2016	10:18:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	021F	Classroom Faucet Hot Room A110	CF	Lead	0.0013	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-040	Martin, Dan	12/17/2016	10:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	021F	Classroom Faucet Hot Room A110	CF	Copper	0.223	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-040	Martin, Dan	12/17/2016	10:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	021P	Classroom Faucet Hot Room A110	CF	Lead	0.0015	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-039	Martin, Dan	12/17/2016	10:20:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	021P	Classroom Faucet Hot Room A110	CF	Copper	0.253	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-039	Martin, Dan	12/17/2016	10:20:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	022F	Classroom Faucet ColdRoom A111	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-042	Martin, Dan	12/17/2016	11:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	022F	Classroom Faucet ColdRoom A111	CF	Copper	0.205	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-042	Martin, Dan	12/17/2016	11:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	022P	Classroom Faucet ColdRoom A111	CF	Lead	0.0293	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-041	Martin, Dan	12/17/2016	11:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	022P	Classroom Faucet ColdRoom A111	CF	Copper	0.362	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-041	Martin, Dan	12/17/2016	11:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	023F	Classroom Faucet Hot Room A111	CF	Lead	0.0015	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-044	Martin, Dan	12/17/2016	10:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	023F	Classroom Faucet Hot Room A111	CF	Copper	0.266	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-044	Martin, Dan	12/17/2016	10:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	023P	Classroom Faucet Hot Room A111	CF	Lead	0.0234	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-043	Martin, Dan	12/17/2016	10:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	023P	Classroom Faucet Hot Room A111	CF	Copper	0.317	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-043	Martin, Dan	12/17/2016	10:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	024F	Classroom Faucet Hot Room A111	CF	Lead	0.0019	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-046	Martin, Dan	12/17/2016	11:15:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	024F	Classroom Faucet Hot Room A111	CF	Copper	0.279	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-046	Martin, Dan	12/17/2016	11:15:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	024P	Classroom Faucet Hot Room A111	CF	Lead	0.0020	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-045	Martin, Dan	12/17/2016	11:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	024P	Classroom Faucet Hot Room A111	CF	Copper	0.404	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-045	Martin, Dan	12/17/2016	11:14:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	025F	Classroom Faucet Cold Room A111	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-048	Martin, Dan	12/17/2016	11:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	025F	Classroom Faucet Cold Room A111	CF	Copper	0.176	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-048	Martin, Dan	12/17/2016	11:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	025P	Classroom Faucet Cold Room A111	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-047	Martin, Dan	12/17/2016	11:17:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	025P	Classroom Faucet Cold Room A111	CF	Copper	0.292	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-047	Martin, Dan	12/17/2016	11:17:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	026F	Classroom Faucet Hot Room B125	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-050	Martin, Dan	12/17/2016	11:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	026F	Classroom Faucet Hot Room B125	CF	Copper	0.218	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-050	Martin, Dan	12/17/2016	11:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	026P	Classroom Faucet Hot Room B125	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-049	Martin, Dan	12/17/2016	11:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	026P	Classroom Faucet Hot Room B125	CF	Copper	0.391	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-049	Martin, Dan	12/17/2016	11:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	027F	Classroom Faucet Cold Room B125	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-052	Martin, Dan	12/17/2016	11:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	027F	Classroom Faucet Cold Room B125	CF	Copper	0.165	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-052	Martin, Dan	12/17/2016	11:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	027P	Classroom Faucet Cold Room B125	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-051	Martin, Dan	12/17/2016	11:23:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	027P	Classroom Faucet Cold Room B125	CF	Copper	0.210	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-051	Martin, Dan	12/17/2016	11:23:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	028F	Classroom Faucet Hot Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-054	Martin, Dan	12/17/2016	11:31:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	028F	Classroom Faucet Hot Room B128	CF	Copper	0.350	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-054	Martin, Dan	12/17/2016	11:31:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	028P	Classroom Faucet Hot Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-053	Martin, Dan	12/17/2016	11:30:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	028P	Classroom Faucet Hot Room B128	CF	Copper	0.325	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-053	Martin, Dan	12/17/2016	11:30:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	029F	Classroom Faucet Cold Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-056	Martin, Dan	12/17/2016	11:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	029F	Classroom Faucet Cold Room B128	CF	Copper	0.155	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-056	Martin, Dan	12/17/2016	11:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	029P	Classroom Faucet Cold Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-055	Martin, Dan	12/17/2016	11:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	029P	Classroom Faucet Cold Room B128	CF	Copper	0.195	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-055	Martin, Dan	12/17/2016	11:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	030F	Classroom Faucet Cold Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-058	Martin, Dan	12/17/2016	11:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	030F	Classroom Faucet Cold Room B128	CF	Copper	0.206	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-058	Martin, Dan	12/17/2016	11:36:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	030P	Classroom Faucet Cold Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-057	Martin, Dan	12/17/2016	11:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	030P	Classroom Faucet Cold Room B128	CF	Copper	0.236	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-057	Martin, Dan	12/17/2016	11:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	031F	Classroom Faucet Hot Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-060	Martin, Dan	12/17/2016	11:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	031F	Classroom Faucet Hot Room B128	CF	Copper	0.440	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-060	Martin, Dan	12/17/2016	11:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	031P	Classroom Faucet Hot Room B128	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-059	Martin, Dan	12/17/2016	11:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	031P	Classroom Faucet Hot Room B128	CF	Copper	0.419	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-059	Martin, Dan	12/17/2016	11:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	032F	Classroom Faucet Hot Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-062	Martin, Dan	12/17/2016	11:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	032F	Classroom Faucet Hot Room B130	CF	Copper	0.379	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-062	Martin, Dan	12/17/2016	11:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	032P	Classroom Faucet Hot Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-061	Martin, Dan	12/17/2016	11:44:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	032P	Classroom Faucet Hot Room B130	CF	Copper	0.359	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-061	Martin, Dan	12/17/2016	11:44:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	033F	Classroom Faucet Cold Room B130	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-064	Martin, Dan	12/17/2016	11:47:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	033F	Classroom Faucet Cold Room B130	CF	Copper	0.177	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-064	Martin, Dan	12/17/2016	11:47:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	033P	Classroom Faucet Cold Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-063	Martin, Dan	12/17/2016	11:47:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	033P	Classroom Faucet Cold Room B130	CF	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-063	Martin, Dan	12/17/2016	11:47:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	034F	Classroom Faucet Hot Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-066	Martin, Dan	12/17/2016	11:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	034F	Classroom Faucet Hot Room B130	CF	Copper	0.438	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-066	Martin, Dan	12/17/2016	11:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	034P	Classroom Faucet Hot Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-065	Martin, Dan	12/17/2016	11:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	034P	Classroom Faucet Hot Room B130	CF	Copper	0.373	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-065	Martin, Dan	12/17/2016	11:50:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	035F	Classroom Faucet Cold Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-068	Martin, Dan	12/17/2016	11:52:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	035F	Classroom Faucet Cold Room B130	CF	Copper	0.297	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-068	Martin, Dan	12/17/2016	11:52:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	035P	Classroom Faucet Cold Room B130	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-067	Martin, Dan	12/17/2016	11:52:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	035P	Classroom Faucet Cold Room B130	CF	Copper	0.271	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-067	Martin, Dan	12/17/2016	11:52:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	037F	Nurses Station Cold	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-070	Martin, Dan	12/17/2016	12:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	037F	Nurses Station Cold	NS	Copper	0.173	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-070	Martin, Dan	12/17/2016	12:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	037P	Nurses Station Cold	NS	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-069	Martin, Dan	12/17/2016	12:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	037P	Nurses Station Cold	NS	Copper	0.297	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-069	Martin, Dan	12/17/2016	12:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	038F	Classroom Faucet Hot Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-072	Martin, Dan	12/17/2016	12:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	038F	Classroom Faucet Hot Room B127	CF	Copper	0.402	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-072	Martin, Dan	12/17/2016	12:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	038P	Classroom Faucet Hot Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-071	Martin, Dan	12/17/2016	12:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	038P	Classroom Faucet Hot Room B127	CF	Copper	0.422	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-071	Martin, Dan	12/17/2016	12:10:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	039F	Classroom Faucet Cold Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-074	Martin, Dan	12/17/2016	12:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	039F	Classroom Faucet Cold Room B127	CF	Copper	0.354	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-074	Martin, Dan	12/17/2016	12:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	039P	Classroom Faucet Cold Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-073	Martin, Dan	12/17/2016	12:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	039P	Classroom Faucet Cold Room B127	CF	Copper	0.289	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-073	Martin, Dan	12/17/2016	12:12:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	040F	Classroom Faucet Cold Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-076	Martin, Dan	12/17/2016	12:15:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	040F	Classroom Faucet Cold Room B127	CF	Copper	0.146	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-076	Martin, Dan	12/17/2016	12:15:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	040P	Classroom Faucet Cold Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-075	Martin, Dan	12/17/2016	12:15:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	040P	Classroom Faucet Cold Room B127	CF	Copper	0.318	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-075	Martin, Dan	12/17/2016	12:15:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	041F	Classroom Faucet Hot Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-078	Martin, Dan	12/17/2016	12:20:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	041F	Classroom Faucet Hot Room B127	CF	Copper	0.324	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-078	Martin, Dan	12/17/2016	12:20:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	041P	Classroom Faucet Hot Room B127	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-077	Martin, Dan	12/17/2016	12:20:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	041P	Classroom Faucet Hot Room B127	CF	Copper	0.329	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-077	Martin, Dan	12/17/2016	12:20:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	042F	Classroom Faucet Hot Room B124	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-080	Martin, Dan	12/17/2016	12:25:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	042F	Classroom Faucet Hot Room B124	CF	Copper	0.493	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-080	Martin, Dan	12/17/2016	12:25:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	042P	Classroom Faucet Hot Room B124	CF	Lead	0.0044	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-079	Martin, Dan	12/17/2016	12:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	042P	Classroom Faucet Hot Room B124	CF	Copper	0.167	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-079	Martin, Dan	12/17/2016	12:24:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	043F	Classroom Faucet Cold Room B124	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-082	Martin, Dan	12/17/2016	12:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	043F	Classroom Faucet Cold Room B124	CF	Copper	0.657	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-082	Martin, Dan	12/17/2016	12:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	043P	Classroom Faucet Cold Room B124	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-081	Martin, Dan	12/17/2016	12:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	043P	Classroom Faucet Cold Room B124	CF	Copper	0.640	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-081	Martin, Dan	12/17/2016	12:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	044F	Kitchen Faucet Cold B100.4	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-084	Martin, Dan	12/17/2016	12:37:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	044F	Kitchen Faucet Cold B100.4	KC	Copper	0.191	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-084	Martin, Dan	12/17/2016	12:37:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	044P	Kitchen Faucet Cold B100.4	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-083	Martin, Dan	12/17/2016	12:37:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	044P	Kitchen Faucet Cold B100.4	KC	Copper	0.251	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-083	Martin, Dan	12/17/2016	12:37:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	045F	Kitchen Faucet Hot B100.4	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-086	Martin, Dan	12/17/2016	12:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	045F	Kitchen Faucet Hot B100.4	KC	Copper	0.354	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-086	Martin, Dan	12/17/2016	12:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	045P	Kitchen Faucet Hot B100.4	KC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-085	Martin, Dan	12/17/2016	12:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	045P	Kitchen Faucet Hot B100.4	KC	Copper	0.350	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-085	Martin, Dan	12/17/2016	12:38:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	048F	Water Cooler Cafe	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-088	Martin, Dan	12/17/2016	13:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	048F	Water Cooler Cafe	WC	Copper	0.162	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-088	Martin, Dan	12/17/2016	13:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	048P	Water Cooler Cafe	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-087	Martin, Dan	12/17/2016	12:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	048P	Water Cooler Cafe	WC	Copper	0.156	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-087	Martin, Dan	12/17/2016	12:59:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	049F	Water Cooler Cafe	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-090	Martin, Dan	12/17/2016	13:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	049F	Water Cooler Cafe	WC	Copper	0.165	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-090	Martin, Dan	12/17/2016	13:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	049P	Water Cooler Cafe	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-089	Martin, Dan	12/17/2016	13:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	049P	Water Cooler Cafe	WC	Copper	0.161	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-089	Martin, Dan	12/17/2016	13:05:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	050F	Water Cooler Outside D111	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-092	Martin, Dan	12/17/2016	13:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	050F	Water Cooler Outside D111	WC	Copper	0.127	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-092	Martin, Dan	12/17/2016	13:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	050P	Water Cooler Outside D111	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-091	Martin, Dan	12/17/2016	13:26:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	050P	Water Cooler Outside D111	WC	Copper	0.141	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-091	Martin, Dan	12/17/2016	13:26:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	051F	Water Cooler Outside Room D111	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-094	Martin, Dan	12/17/2016	13:35:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	051F	Water Cooler Outside Room D111	WC	Copper	0.129	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-094	Martin, Dan	12/17/2016	13:35:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	051P	Water Cooler Outside Room D111	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-093	Martin, Dan	12/17/2016	13:35:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	051P	Water Cooler Outside Room D111	WC	Copper	0.156	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-093	Martin, Dan	12/17/2016	13:35:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	052F	Classroom Faucet Cold Room D105	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-096	Martin, Dan	12/17/2016	13:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	052F	Classroom Faucet Cold Room D105	CF	Copper	0.251	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-096	Martin, Dan	12/17/2016	13:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	052P	Classroom Faucet Cold Room D105	CF	Lead	0.0050	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-095	Martin, Dan	12/17/2016	13:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	052P	Classroom Faucet Cold Room D105	CF	Copper	0.169	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-095	Martin, Dan	12/17/2016	13:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	053F	Classroom Faucet Hot Room D105	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-098	Martin, Dan	12/17/2016	13:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	053F	Classroom Faucet Hot Room D105	CF	Copper	0.334	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-098	Martin, Dan	12/17/2016	13:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	053P	Classroom Faucet Hot Room D105	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-097	Martin, Dan	12/17/2016	13:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	053P	Classroom Faucet Hot Room D105	CF	Copper	0.495	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-097	Martin, Dan	12/17/2016	13:50:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	054F	Classroom Faucet Cold Room D104	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-100	Martin, Dan	12/17/2016	14:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	054F	Classroom Faucet Cold Room D104	CF	Copper	0.156	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-100	Martin, Dan	12/17/2016	14:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	054P	Classroom Faucet Cold Room D104	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-099	Martin, Dan	12/17/2016	14:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	054P	Classroom Faucet Cold Room D104	CF	Copper	0.328	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-099	Martin, Dan	12/17/2016	14:00:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	055F	Classroom Faucet Hot Room D104	CF	Lead	0.0012	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-102	Martin, Dan	12/17/2016	14:01:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	055F	Classroom Faucet Hot Room D104	CF	Copper	0.462	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-102	Martin, Dan	12/17/2016	14:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	055P	Classroom Faucet Hot Room D104	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-101	Martin, Dan	12/17/2016	14:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	055P	Classroom Faucet Hot Room D104	CF	Copper	0.347	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-101	Martin, Dan	12/17/2016	14:01:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	056F	Water Cooler Outside Girls Locker Room	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-104	Martin, Dan	12/17/2016	14:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	056F	Water Cooler Outside Girls Locker Room	WC	Copper	0.240	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-104	Martin, Dan	12/17/2016	14:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	056P	Water Cooler Outside Girls Locker Room	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-103	Martin, Dan	12/17/2016	14:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	056P	Water Cooler Outside Girls Locker Room	WC	Copper	0.267	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-103	Martin, Dan	12/17/2016	14:06:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	057F	Water Cooler Outside Boys Locker Room	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-106	Martin, Dan	12/17/2016	14:11:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	057F	Water Cooler Outside Boys Locker Room	WC	Copper	0.244	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-106	Martin, Dan	12/17/2016	14:11:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	057P	Water Cooler Outside Boys Locker Room	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-105	Martin, Dan	12/17/2016	14:11:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	057P	Water Cooler Outside Boys Locker Room	WC	Copper	0.242	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-105	Martin, Dan	12/17/2016	14:11:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	058F	Classroom Faucet Cold Room C201.3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-108	Martin, Dan	12/17/2016	14:21:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	058F	Classroom Faucet Cold Room C201.3	CF	Copper	0.134	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-108	Martin, Dan	12/17/2016	14:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	058P	Classroom Faucet Cold Room C201.3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-107	Martin, Dan	12/17/2016	14:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	058P	Classroom Faucet Cold Room C201.3	CF	Copper	0.128	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-107	Martin, Dan	12/17/2016	14:21:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	059F	Classroom Faucet Hot Room C201.3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-110	Martin, Dan	12/17/2016	14:28:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	059F	Classroom Faucet Hot Room C201.3	CF	Copper	0.246	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-110	Martin, Dan	12/17/2016	14:28:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	059P	Classroom Faucet Hot Room C201.3	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-109	Martin, Dan	12/17/2016	14:27:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	059P	Classroom Faucet Hot Room C201.3	CF	Copper	0.267	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-109	Martin, Dan	12/17/2016	14:27:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	060F	Classroom Faucet Cold Room B203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-112	Martin, Dan	12/17/2016	14:40:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	060F	Classroom Faucet Cold Room B203	CF	Copper	0.0746	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-112	Martin, Dan	12/17/2016	14:40:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	060P	Classroom Faucet Cold Room B203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-111	Martin, Dan	12/17/2016	14:31:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	060P	Classroom Faucet Cold Room B203	CF	Copper	0.243	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-111	Martin, Dan	12/17/2016	14:31:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	061F	Classroom Faucet Hot Room B203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-114	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	061F	Classroom Faucet Hot Room B203	CF	Copper	0.298	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-114	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	061P	Classroom Faucet Hot Room B203	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-113	Martin, Dan	12/17/2016	14:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	061P	Classroom Faucet Hot Room B203	CF	Copper	0.299	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-113	Martin, Dan	12/17/2016	14:33:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	063F	Water Cooler Outside LG2	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-116	Martin, Dan	12/17/2016	14:34:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	063F	Water Cooler Outside LG2	WC	Copper	0.296	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-116	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	063P	Water Cooler Outside LG2	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-115	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	063P	Water Cooler Outside LG2	WC	Copper	0.311	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-115	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	064F	Water Cooler Outside Bathrooms 3rd Floor	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-118	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	064F	Water Cooler Outside Bathrooms 3rd Floor	WC	Copper	0.0793	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-118	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	064P	Water Cooler Outside Bathrooms 3rd Floor	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-117	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	064P	Water Cooler Outside Bathrooms 3rd Floor	WC	Copper	0.0795	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-117	Martin, Dan	12/17/2016	14:34:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	065F	Water Cooler Outside Janitors Closet 3rd Floor	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-120	Martin, Dan	12/17/2016	14:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	065F	Water Cooler Outside Janitors Closet 3rd Floor	WC	Copper	0.0762	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-120	Martin, Dan	12/17/2016	14:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	065P	Water Cooler Outside Janitors Closet 3rd Floor	WC	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-119	Martin, Dan	12/17/2016	14:36:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	065P	Water Cooler Outside Janitors Closet 3rd Floor	WC	Copper	0.0777	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-119	Martin, Dan	12/17/2016	14:36:00	11-Jan-17

Tewksbury- Memorial High School 12-17-2016

LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	066P	Classroom Faucet Hot Teachers Work Room 3rd Floor	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-121	Martin, Dan	12/17/2016	14:40:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	066P	Classroom Faucet Hot Teachers Work Room 3rd Floor	CF	Copper	0.0762	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-121	Martin, Dan	12/17/2016	14:40:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	067F	Classroom Faucet Cold Teachers Work Room 3rd Floor	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-123	Martin, Dan	12/17/2016	14:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	067F	Classroom Faucet Cold Teachers Work Room 3rd Floor	CF	Copper	0.147	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-123	Martin, Dan	12/17/2016	14:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	067P	Classroom Faucet Cold Teachers Work Room 3rd Floor	CF	Lead	ND	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-122	Martin, Dan	12/17/2016	14:45:00	11-Jan-17
LCCA	Tewksbury	02950505	Tewksbury Memorial High	Public School	067P	Classroom Faucet Cold Teachers Work Room 3rd Floor	CF	Copper	0.155	mg/L	0.001	EPA 200.8	GRANITE STATE ANALYTICAL SERVICES LLC	1612-01970-122	Martin, Dan	12/17/2016	14:45:00	11-Jan-17